

SUBDIVISION COMMITTEE  
METROPOLITAN AREA PLANNING COMMISSION

AGENDA ITEM NO. 14  
December 10, 1998

STAFF REPORT  
(One-Step Final Plat)

CASE NUMBER: S/D 98-106 - AYRES ADDITION

OWNER/APPLICANT: Everett Ayres, 8640 S. 263rd St. West, Viola, KS 67149

SURVEYOR/ENGINEER: Terra Tech Land Surveying, Inc., Attn: Michele Goodrich, 239 N. Ohio, Wichita, KS 67214

LOCATION: North of 47th St. South, on the East side of 295th St. West

SITE SIZE: 21.7 acres

NUMBER OF LOTS


Residential:	4
Office:	
Commercial:	
Industrial:	
Total:	<u>4</u>

MINIMUM LOT AREA: 4.6 acres

CURRENT ZONING: RR, Rural Residential

PROPOSED ZONING: Same

VICINITY MAP



Note: This site is located in the County in an area designated as "agricultural" by the Wichita-Sedgwick County Comprehensive Plan. Lot developments of this type are contrary to the intent of the Comprehensive Plan; however, the MAPC and County Commission have chosen not to create an Agricultural Zoning District to protect against this type of development.

STAFF COMMENTS:

- A. Since neither municipal water nor sanitary sewer is available to serve this property, the applicant shall contact the Environmental Health Division of the Health Department to find out what tests may be necessary and what standards are to be met for approval of on-site sewerage facilities and water wells. A memorandum shall be obtained specifying approval.
- B. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning department for recording.
- C. County Engineering needs to comment on the status of the applicant's drainage plan.
- D. The Applicant intends to establish an access easement by separate instrument across Lot 3 for access to Lot 4. This easement shall be denoted on the final plat tracing.
- E. The final plat tracing shall indicate the dedication of access controls as the site adjoins a mile line road. Lot 3 shall be limited to one opening at the location of the access easement.
- F. The Zoning regulations require a setback of 85 feet from the centerline of a section line road. A 35-foot setback will be needed.
- G. The plattor's text should reference that the contingent right-of-way shall become effective "upon the platting of any adjacent subdivision having a street connecting thereto".
- H. County Fire should be contacted regarding the designation of a street name for the contingent right-of-way.
- I. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article

8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)

- J. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- K. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (phone 316-729-0102) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- L. The applicant is advised that various State and Federal requirements [specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147] for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- M. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- N. Perimeter closure computations shall be submitted with the final plat tracing..
- O. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.
- P. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.
- Q. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in Release 13 version of Autocad. This will be used by the City and County GIS Department.