

STAFF REPORT
(One-Step Final Plat)

CASE NUMBER: SUB 2006-101 -- GROENDYKE TRANSPORT ADDITION

OWNER/APPLICANT: Groendyke Transport Inc., P.O. Box 632, Enid, OK 73702

AGENT: K. E. Miller Engineering, PA., Attn: Kirk Miller, 516 S. Market, Wichita, KS 67202

SURVEYOR: Savoy Company, P.A., 535 S. Emporia, Suite 104, Wichita, KS 67202

LOCATION: North of 29th St. North, West of Hydraulic

SITE SIZE: 17.4 acres

NUMBER OF LOTS


Residential:	
Office:	
Commercial:	
Industrial:	1
Total:	1

MINIMUM LOT AREA: 17.4 acres

CURRENT ZONING: GI, General Industrial

PROPOSED ZONING: Same

VICINITY MAP



NOTE: This is an unplatted site located within the City.

STAFF COMMENTS:

- A. City water and sewer services are available to serve the site. The applicant is advised that sewer is available only at the three manholes located in the right-of-way on the east side of Ohio.
- B. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning Department for recording.
- C. City Engineering needs to comment on the status of the applicant's drainage plan.
- D. City Engineering has requested the applicant participate in a paving petition for 33rd St. North. In the alternative, the applicant may request a vacation request for 33rd St. North with adjoining property owners.
- E. The Applicant is reminded that a platting binder is required with the final plat. Approval of this plat will be subject to submittal of this binder and any relevant conditions found by such a review.
- F. The plat's text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.
- G. The applicant shall install or guarantee the installation of all utilities and facilities that are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- H. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- I. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (Phone: 316-946-4556) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- J. The applicant is advised that various State and Federal requirements (specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147) for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- K. The owner of the subdivision should note that any construction that results in earthwork activities that will disturb one (1) acre or more of ground cover requires a Federal/State NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Also, for projects located within the City of Wichita, erosion and sediment control devices must be used on ALL projects. For projects outside of the City of Wichita, but within the Wichita Metropolitan area, the owner should contact the appropriate governmental jurisdiction concerning erosion and sediment control device requirements.

- L. *Perimeter closure computations shall be submitted with the final plat tracing.*
- M. Recording of the plat within 30 days after approval by the City Council and/or County Commission.
- N. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.
- O. A compact disc (CD), which will be used by the City and County GIS Departments, detailing the final plat in digital format in AutoCAD. If a disc is not provided, please send via e-mail to Cheryl Holloway (E-Mail address: cholloway@wichita.gov). Please include the name of the plat on the disc.