

STAFF REPORT
(One-Step Final Plat)

CASE NUMBER: SUB 2000-45 -- MID CONTINENT AIRPORT 2nd ADDITION

OWNER/APPLICANT: Wichita Airport Authority, Attn: Bailis Bell, Director of Airports, P.O. Box 9130, Wichita, KS 67209-0139

SURVEYOR/ENGINEER: PEC, P.A., Attn: Gary Wiley, 303 S. Topeka, Wichita, KS 67202

LOCATION: Northwest corner of Harry and Ridge Road

SITE SIZE: 10.15 Acres

NUMBER OF LOTS


Residential:	
Office:	
Commercial:	
Industrial:	1
Total:	1

MINIMUM LOT AREA: 10.15 Acres

CURRENT ZONING: Limited Industrial

PROPOSED ZONING: Same

VICINITY MAP



Note: This is an unplatted site located within the City.

STAFF COMMENTS:

- A. Municipal services appear to be available to serve the site. City Engineering needs to comment on the need for any guarantees or easements.
- B. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning department for recording.
- C. City Engineering needs to comment on the status of the applicant's drainage plan.
- D. Traffic Engineering needs to comment on the need for access controls to Harry (a collector street) and Ridge Road. Distances should be shown for all segments of access control.
- E. The applicant shall submit an avigational easement covering all of the subject plat and a restrictive covenant assuring that adequate construction methods will be used to minimize the effects of noise pollution in the habitable structures constructed on subject property.
- F. The plattor's text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.
- G. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- H. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- I. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (Phone 316-729-0102) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- J. The applicant is advised that various State and Federal requirements (specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147) for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- K. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- L. Perimeter closure computations shall be submitted with the final plat tracing.
- M. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.

- N. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.
- O. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in AutoCAD. This will be used by the City and County GIS Department.

**MID-CONTINENT AIRPORT
2ND ADDITION PLAT BOUNDARY**

501 North: 10050.0000 East : 9950.4536
 Line Course: N 90-00-00 W Length: 391.12'

500 North: 10050.0000 East : 9559.3291
 Line Course: N 00-29-30 E Length: 511.16'

2011 North: 10561.1431 East : 9563.7160
 Line Course: N 04-45-03 W Length: 581.40'

2010 North: 11140.5456 East : 9515.5631
 Line Course: N 89-59-57 E Length: 444.83'

502 North: 11140.5519 East : 9960.3916
 Line Course: S 00-31-20 W Length: 1090.60'

501 North: 10050.0000 East : 9950.4536

Perimeter: 3019.11' Area: 442,246 sq.ft. 10.15 acres

MID-CONTINENT AIRPORT
2ND ADDITION PLAT BOUNDARY

501 North: 10050.0000 East : 9950.4536
Line Course: N 90-00-00 W Length: 391.12'

500 North: 10050.0000 East : 9559.3291
Line Course: N 00-29-30 E Length: 511.16'

2011 North: 10561.1431 East : 9563.7160
Line Course: N 04-45-03 W Length: 581.40'

2010 North: 11140.5456 East : 9515.5631
Line Course: N 89-59-57 E Length: 444.83'

502 North: 11140.5519 East : 9960.3916
Line Course: S 00-31-20 W Length: 1090.60'

501 North: 10050.0000 East : 9950.4536

Perimeter: 3019.11' Area: 442,246 sq.ft. 10.15 acres