

STAFF REPORT
(One-Step Final Plat)

CASE NUMBER: SUB 2000-82 -- SAVANNAH PLACE ADDITION

OWNER/APPLICANT: Savannah Place Apartments, L.L.C., Attn: Bryan Lagaly, 1218 Hickory Creek, Wichita, KS 67235

SURVEYOR/ENGINEER: Savoy, Ruggles & Bohm, 924 N. Main, Wichita, KS 67203

LOCATION: West side of Tyler, South of Maple

SITE SIZE: 3.6 Acres

NUMBER OF LOTS


Residential:	
Office:	
Commercial:	2
Industrial:	
Total:	2

MINIMUM LOT AREA: 1.53 Acres

CURRENT ZONING: NR, Neighborhood Retail uses per CUP

PROPOSED ZONING: Same

VICINITY MAP



Note: This site is a replat of Lots 1 and 2 of the Westwood Hills 3rd Addition and subject to the Westwood Hills CUP (DP-97). This replat proposes the vacation of access controls along Maybelle and University, allowing an additional opening for each lot, in addition to the reduction of setbacks.

STAFF COMMENTS:

SS ext to lot 2

- A. City Engineering has previously obtained petitions for City water and sanitary sewer with the Westwood Hills 3rd Addition. City Engineering needs to comment on the need for any additional guarantees or easements.
- B. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning department for recording.
- C. City Engineering needs to comment on the status of the applicant's drainage plan.
- D. A CUP administrative adjustment will need to be obtained regarding the revised setbacks and access controls.
- E. The applicant is reminded that a platting binder is required with the final plat. Approval of this plat will be subject to submittal of this binder and any relevant conditions found by such a review.
- F. As required by the sidewalk ordinance, sidewalks shall be provided along University Avenue and Maybelle Avenue. A sidewalk certificate was previously obtained with the Westwood Hills 3rd Addition.
- G. The platting text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.
- H. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- I. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- J. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (phone 316-729-0102) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- K. The applicant is advised that various State and Federal requirements [specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147] for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.

- L. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- M. Perimeter closure computations shall be submitted with the final plat tracing.
- N. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.
- O. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.
- P. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in Release 13 version of AutoCAD. This will be used by the City and County GIS Department.

BOUNDARY CLOSURE:
SAVANNAH PLACE ADDITION
WICHITA, SEDGWICK COUNTY, KANSAS

North: 19623.648	East: 19950.000
Line Course: S 00-00-00 W	Length: 30.00
North: 19593.648	East: 19950.000
Line Course: S 89-53-00 W	Length: 200.00
North: 19593.241	East: 19750.000
Line Course: S 00-00-00 W	Length: 213.34
North: 19379.901	East: 19750.000
Line Course: N 90-00-00 W	Length: 370.00
North: 19379.901	East: 19380.000
Line Course: N 00-00-00 E	Length: 423.84
North: 19803.741	East: 19380.000
Line Course: N 89-53-00 E	Length: 330.00
North: 19804.413	East: 19710.000
Line Course: S 00-00-00 W	Length: 181.25
North: 19623.163	East: 19710.000
Line Course: N 89-53-00 E	Length: 240.00
North: 19623.652	East: 19949.999

Perimeter: 1988.43 Area: 155,709. sq.ft. 3.57 acres

Mapcheck Closure - (Uses listed courses and chords)

Error Closure: 0.003	Course: N 12-42-48 W
Error North: 0.0034	East: -0.0008
Precision 1: 570,504.24	