

SCANNED

STAFF REPORT
(One-Step Final Plat)

CASE NUMBER: SUB 2008-33 – RIVER OAKS MOBILE HOME PARK 2ND ADDITION

OWNER/APPLICANT: Mobile Home Living, Inc., 2320 E. MacArthur, Wichita, KS 67216

SURVEYOR/AGENT: Ruggles & Bohm, P.A., Attn: Tom Ruggles, 924 N. Main, Wichita, KS 67203

LOCATION: East of Hydraulic, North side of 55th St. South (extended) (District III)

SITE SIZE: 2.29 acres

NUMBER OF LOTS


Residential:	1
Office:	
Commercial:	
Industrial:	
Total:	1

MINIMUM LOT AREA: 2.29 acres

CURRENT ZONING: MH, Manufactured Housing

PROPOSED ZONING: Same

VICINITY MAP



NOTE: This is a replat of Reserve C in the River Oaks Mobile Home Park Addition in addition to unplatted land to the east.

STAFF COMMENTS:

- A. Water and sewer services are available, however the 10-inch sanitary sewer main is the only sewer that is available for individual services.
- B. If improvements are guaranteed by petition(s), a notarized certificate listing the petition(s) shall be submitted to the Planning Department for recording.
- C. City Engineering needs to comment on the status of the applicant's drainage concept.
- D. Provisions shall be made for ownership and maintenance of the proposed reserves. A covenant shall be submitted regarding ownership and maintenance responsibilities.
- E. This property is within a zone identified by the City Engineers' office as likely to have groundwater at some or all times within 10 feet of the ground surface elevation. Building with specially engineered foundations or with the lowest floor opening above groundwater is recommended, and owners seeking building permits on this property will be similarly advised. More detailed information on recorded groundwater elevations in the vicinity of this property is available in the City Engineers' office.
- F. The platting binder indicates a party holding a mortgage on the site. This party's name must be included as a signatory on the plat, or else documentation provided indicating that such mortgage has been released.
- G. The platting text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.
- H. The applicant shall install or guarantee the installation of all utilities and facilities that are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- I. The Register of Deeds requires all names to be printed beneath the signatures on the plat and any associated documents.
- J. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the United States Postal Service Growth Management Coordinator (Phone: 316-946-4556) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- K. The applicant is advised that various State and Federal requirements (specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147) for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- L. The owner of the subdivision should note that any construction that results in earthwork activities that will disturb one (1) acre or more of ground cover requires a Federal/State National Pollutant Discharge Elimination System Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Also, for projects located within the City of Wichita, erosion and sediment control devices must be used on ALL projects. For projects outside of the City of Wichita, but within the Wichita Metropolitan area, the owner should contact the appropriate governmental jurisdiction concerning erosion and sediment control device requirements.
- M. Perimeter closure computations shall be submitted with the final plat tracing.
- N. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.
- O. A compact disc (CD), which will be used by the City and County GIS Departments, detailing the final plat in digital format in AutoCAD. If a disc is not provided, please send via e-mail to Cheryl Holloway (E-Mail address: cholloway@wichita.gov). Please include the name of the plat on the disc.



Date: 4-29-08

MEMO

To: Scott Lindebak

Description:

- Confirmation
- Transmittal
- Transmittal under separate cover by

From: Tom Ruggles

Purpose:

- Approval
- Review & comment
- Use
- Other: _____
- Distribution
- Information
- Record

Project: River Oaks Mobile Home Park
2nd Addition

RB Project No.: 3227E

Enclosures/Attachments:

- Prints
- Originals
- Diskettes containing: _____
- Other: _____
- Change Order
- Shop Drawings

Other Project Reference No.:
SUB 2008-33

Copies	Description
1	Drainage and Utilities Plan
1	Preliminary and Final Plats
1	Plat of River Oaks Mobile Home Park
1	Firmette

Remarks: Please review the enclosed drainage plan for the plat submitted 4-23-08.

Copies to:

If checked below, please:

- Acknowledge receipt of enclosures
- Return enclosures to us.

Signed _____



SCANNED Ruggles & Bohm, P.A

Engineering, Surveying, Land Planning
924 N. Main
Wichita, Kansas 67203

Date: 4-29-08 5-15-08

MEMO

To: Scott Lindebak Julianne Kallman

Description:

- Confirmation
- Transmittal
- Transmittal under separate cover by

From: Tom Ruggles

Purpose:

- Approval
- Review & comment
- Use
- Other : _____
- Distribution
- Information
- Record

Project: River Oaks Mobile Home Park
2nd Addition

Enclosures/Attachments:

- Prints
- Originals
- Diskettes containing: _____
- Change Order
- Shop Drawings

RB Project No.: 3227E

Other Project Reference No.:
SUB 2008-33

Other: _____

Copies	Description
1	Drainage and Utilities Plan
1	Preliminary and Final Plats
1	Plat of River Oaks Mobile Home Park
1	Firmette


Remarks: Please review the enclosed drainage plan for the plat submitted 4-23-08.


Copies to: _____

If checked below, please:


- Acknowledge receipt of enclosures
- Return enclosures to us.

Signed _____





Powered by GeoSmart.net



5201

5553

354

22

1801

5450

64

S SPRUCE AVE

64

E MAYWOOD ST

2102

2243

E 4TH ST S

5460

E CAMPUS ST

27