

Lindebak, Scott

From: Alex Lane [alane@rbkansas.com]
Sent: Tuesday, June 30, 2009 3:51 PM
To: Lindebak, Scott
Subject: B.G.'s 1st Addition

Scott,

I wanted to touch base about the proposed flume you were concerned about on the above referenced project. I did confirm that the reason for the flume instead of an inlet was the presence of the gas lines on the west side of Hoover. I am in the process of getting the pipelines probed to determine what the options will be for getting the drainage from the cul-de-sac to the ditch. I will let you know as soon as I have something to report. I will certainly revise the drainage report as needed to avoid delaying the plat.

Alex M. Lane, P.E.
Ruggles & Bohm P.A.
Ph. (316)264-8008
Fax (316)264-4621

Electronic files are transmitted herewith for information only. It is the responsibility of any user to verify any information contained in these files.