

**STAFF REPORT**  
**(One-Step Final Plat)**

**CASE NUMBER:** SUB 2009-20 -- RED ROCK VILLAGE ADDITION

**OWNER/APPLICANT:** Development Partnership, Attn: Mark Chappelle, 9414 W. Central, Wichita, KS 67212

**SURVEYOR/AGENT:** Ruggles & Bohm, P.A., Attn: Tom Ruggles, 924 N. Main, Wichita, KS 67203

**LOCATION:** East of 135<sup>TH</sup> St. West, South side of Pawnee (District IV)

**SITE SIZE:** 11.86 acres

**NUMBER OF LOTS**


Residential:	43
Office:	
Commercial:	
Industrial:	
Total:	<u>43</u>

**MINIMUM LOT AREA:** 5,175 square feet

**CURRENT ZONING:** SF-5 Single-family Residential

**PROPOSED ZONING:** Same

**VICINITY MAP**



**SUB 2009-20 -- One-Step Final Plat of RED ROCK VILLAGE ADDITION  
March 26, 2009 - Page 2**

**NOTE:** An overall preliminary plat was approved for the site in 2006. This revised preliminary plat and final plat represents the second phase of development. It is a replat of Reserves B and C in the Southwest Passage Addition in addition to unplatted property. The street layout and lot configuration have been revised reflecting an additional 6 lots.

**STAFF COMMENTS:**

- A. City of Wichita Water Utilities Department requests a petition for extension of sanitary sewer (mains and laterals) to all lots being platted. The applicant needs to obtain a service area release from Sedgwick County Rural Water District #4 prior to being served with water.
- B. If improvements are guaranteed by petition(s), a notarized certificate listing the petition(s) shall be submitted to the Planning Department for recording.
- C. City Engineering needs to comment on the status of the applicant's drainage plan.
- D. The plat proposes one street opening along Pawnee in conformance with the original overall preliminary plat.
- E. The Applicant shall guarantee the paving of the proposed streets. The guarantee shall also provide for sidewalks on at least one side of all through, non cul-de-sac streets.
- F. Since this plat proposes the platting of a 32-foot narrow street right-of-way, adjacent 15-foot street, drainage and utility easements are needed.
- G. In accordance with the Kansas Wetland Mapping Conventions under the Memorandum of Understanding between the United States Department of Agriculture - Natural Resources Conservation Service; United States Environmental Protection Agency; United States Army Corps of Engineer (USACE); and United States Fish and Wildlife Service, this site has been identified as one with potential wetland hydrology. The USACE should be contacted (316-322-8247) to have a wetland determination completed.
- H. Provisions shall be made for ownership and maintenance of the proposed reserves. The applicant shall either form a lot owners' association prior to recording the plat or shall submit a covenant stating when the association will be formed, when the reserves will be deeded to the association and who is to own and maintain the reserves prior to the association taking over those responsibilities.
- I. For those reserves being platted for drainage purposes, the required covenant that provides for ownership and maintenance of the reserves, shall grant to the appropriate governing body the authority to maintain the drainage reserves in the event the owner(s) fail to do so. The covenant shall provide for the cost of such maintenance to be charged back to the owner(s) by the governing body.
- J. The applicant shall submit a covenant that provides four (4) off-street parking spaces per lot that abuts a 32-foot or 58-foot street. The covenant shall inventory the affected lots by lot and block number and shall state that the covenant runs with the land and is binding on future owners and assigns.
- K. The Applicant has platted a 20-foot building setback along Blocks 3 and 4 which represents an adjustment of the Zoning Code standard of 25 feet for the SF-5 Single-family District. The Subdivision Regulations permit the setback provisions to be modified by the plat upon the approval of the Planning Commission.
- L. GIS has approved the plat's street names.
- M. The plat's text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.
- N. The applicant shall install or guarantee the installation of all utilities and facilities that are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- O. The Register of Deeds requires all names to be printed beneath the signatures on the plat and any associated documents.

- P. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the United States Postal Service Growth Management Coordinator (Phone: 316-946-4556) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- Q. The applicant is advised that various State and Federal requirements (specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147) for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- R. The owner of the subdivision should note that any construction that results in earthwork activities that will disturb one (1) acre or more of ground cover requires a Federal/State National Pollutant Discharge Elimination System Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Also, for projects located within the City of Wichita, erosion and sediment control devices must be used on ALL projects. For projects outside of the City of Wichita, but within the Wichita Metropolitan area, the owner should contact the appropriate governmental jurisdiction concerning erosion and sediment control device requirements.
- S. Perimeter closure computations shall be submitted with the final plat tracing.
- T. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.
- U. A compact disc (CD), which will be used by the City and County GIS Departments, detailing the final plat in digital format in AutoCAD. If a disc is not provided, please send via e-mail to Cheryl Holloway (E-Mail address: cholloway@wichita.gov). Please include the name of the plat on the disc.