

Lindebak, Scott

From: Les Mangus [lmangus@andoverks.com]
Sent: Monday, June 27, 2011 8:45 AM
To: Lindebak, Scott; 'Greg Allison'; 'Jim Ubert'
Subject: RE: Monarch Landing 3rd Addition

Scott,

The City of Andover has reviewed the plan for a storm sewer connection to the system in 159th St. near Keystone Pkwy. and has no objection. The system was designed to accept offsite drainage at that point.
Les

From: Lindebak, Scott [mailto:SLindebak@wichita.gov]
Sent: Sunday, June 26, 2011 8:39 AM
To: Greg Allison; Jim Ubert
Cc: Les Mangus
Subject: Monarch Landing 3rd Addition

Greg,

Based on the email chains below, it is unclear that the City of Andover has approved or accepted the City of Wichita connecting a stormwater conduit to serve Monarch Landing 3rd Addition, into an Andover stormwater system in 159th Street East, north of 21st Street North.

Thanks!

Scott

From: Greg Allison [mailto:gallison@Mkec.com]
Sent: Wednesday, June 22, 2011 10:23 PM
To: Jim Ubert
Cc: Lindebak, Scott; Les Mangus (lmangus@andoverks.com)
Subject: Re: Monarch Landing

Thanks Jim and Les for review of this information.

Greg Allison

On Jun 22, 2011, at 11:10 AM, Jim Ubert <Jim.Ubert@poeandassociates.com> wrote:

Scott

Greg Allison provided a drainage report for Monarch Landing 3rd and talked with me about it.

His report indicates that the post development is less than the pre-development (all rain events) and the plan shows extending a storm sewer system form an existing curb inlet in 159th (that was designed and constructed with an apron on the backside of it for the drainage on west side of 159th).

Jim Ubert

POE & ASSOCIATES, INC.

5940 E. Central, Suite 200

Wichita, KS 67208

316-685-4114 phone

316-685-4444 fax

Jim.Ubert@poeandassociates.com