

## Lindebak, Scott

---

**From:** Scott Servis [Scott.Servis@poeandassociates.com]  
**Sent:** Wednesday, February 20, 2013 4:48 PM  
**To:** Lindebak, Scott  
**Cc:** Tim Austin  
**Subject:** Mac West Drainage Study  
**Attachments:** Drainage Report.pdf

Scott,

Attached are revised sheets for the Mac West Drainage Study. I revised section 3.3.2 to state that curve numbers shall be revised in the event total site imperviousness exceeds the 70% currently anticipated.

I also revised section 3.3.9 to require areas A and B to provide their own detention. These are the only changes. Everything else in the attached .pdf is as submitted yesterday.

These revisions address all remaining comments we have received since we met at your office yesterday afternoon. I assume we are on for tomorrow's MAPC meeting.

**Scott R. Servis, PE**  
*Poe & Associates, Inc.*  
5940 E. Central, Suite 200  
Wichita, KS 67208  
316-685-4114 (O)  
316-685-4444 (F)  
316-680-6661 (C)

[scott.servis@poeandassociates.com](mailto:scott.servis@poeandassociates.com)