### STAFF REPORT (Sketch Plat)

**CASE NUMBER:** SUB2023-00015 – FALCON FALLS EAST 2<sup>ND</sup> ADDITION (City)

**OWNER/APPLICANT:** Bell Land Holdings LLC, Attn: Jay Russell, PO Box 75337, Wichita, KS

67275

**SURVEYOR/AGENT:** Baughman Company, P.A., Attn: Kris Rose, 315 Ellis, Wichita, KS

67211

**LOCATION:** East side of North Hillside Avenue, within one-half mile north of East

45<sup>th</sup> Street North (District I)

**SITE SIZE:** 60 acres

**NUMBER OF LOTS** 

Residential: 102

Office:

Commercial:

Industrial:

Total:  $\overline{102}$ 

MINIMUM LOT AREA: 8,844 square feet

**CURRENT ZONING:** SF-5 Single-Family Residential, MF-18 Multi-Family Residential

**PROPOSED ZONING:** TF-3 Two-Family Residential, MF-18 Multi-Family Residential

### **VICINITY MAP**



### SUB2023-00015 – Sketch Plat of FALCON FALLS EAST $2^{ND}$ ADDITION June 1, 2023 - Page 2

**NOTE:** This is a replat of the Falcon Falls East Addition with a revised street layout including a street connection to the south. A zone change (ZON2023-00021) has been requested from SF-5 Single-Family Residential to TF-3 Two-Family Residential for a portion of the site.

The Subdivision Committee may recommend a MODIFICATION/WAIVER of the design criteria in Article 7 of the Subdivision Regulations only if it finds that the strict application of the design criteria will create an unwarranted hardship, the proposed MODIFICATION/WAIVER is in harmony with the intended purpose of the Subdivision Regulations and the public safety and welfare will be protected. (Items N and S)

#### **STAFF COMMENTS:**

A. <u>City of Wichita Public Works and Utilities Department</u> requires water and sanitary sewer be extended for all lots and blocks. Water transmission acquisition fees are owed.

Easements on the face of plat need to be labeled. The waterlines for Vassar Ct's will probably need to be looped to Fairmount Ave. A utility plan is requested.

On the final plat, the plattor's text shall state "No sign, light poles, private drainage systems, berms, walls, masonry trash enclosures or other structures shall be located within public utility easements unless permitted by the City of Wichita Department of Engineering and that they do not inhibit the conveyance of surface drainage."

On the final plat, the plattor's text shall state, "No private drainage systems shall be located within public drainage easements unless a Residential Drainage Relief Permit is obtained from the City of Wichita Public Works & Utilities Department."

The plattor's text shall include language that the utility easements are hereby granted to the public as indicated for the construction and maintenance of all public utilities.

The plattor's text shall include language that the drainage and utility easements are hereby granted to the public as indicated for drainage purposes and for the construction and maintenance of all public utilities.

The plattor's text shall include language that the street, drainage and utility easements are hereby granted to the public as indicated for street and drainage purposes and for the construction and maintenance of all public utilities.

The plattor's text shall state the drainage easements are hereby granted to the public as indicated for drainage purposes.

Since the south portion of the plat is zoned MF-18 Multi-Family Residential, the applicant shall submit an Encroachment Agreement to City Public Works prior to submittal of the mylar.

- B. If improvements are guaranteed by petition(s), a notarized certificate listing the petition(s) shall be submitted to the Planning Department for recording.
- C. <u>City Stormwater Management</u> advises the applicant needs to submit a drainage plan for review.
- D. <u>Traffic Engineering</u> has approved the access controls. The plat denotes one street opening along Hillside Avenue. The final plat shall reference the dedication of access controls in the plattor's text.

# SUB2023-00015 – Sketch Plat of FALCON FALLS EAST $2^{\rm ND}$ ADDITION June 1, 2023 - Page 3

- E. The Applicant shall guarantee the paving of the proposed streets to City standards. In accordance with the Subdivision Regulations, the cul-de-sacs must meet the minimum 35-foot paved radius requirement. The guarantee shall also provide for sidewalks on at least one side of all through and looped non cul-de-sac streets.
- F. In accordance with the Kansas Wetland Mapping Conventions under the Memorandum of Understanding between the United States Department of Agriculture Natural Resources Conservation Service; United States Environmental Protection Agency; United States Army Corps of Engineers (USACE); and United States Fish and Wildlife Service, this site has been identified as one with potential wetland hydrology. The USACE should be contacted (316-322-8247) to have a wetland determination completed.
- G. <u>City Fire Department</u> requests verification of proper hydrant location and protection and following specifications for fire apparatus access roads.

<u>City Fire</u> requires for developments of one or two family dwellings where the number of dwelling units exceeds 30 shall provide two separate and approved fire apparatus access roads. When City Fire requires two fire apparatus access roads, they shall be placed a distance apart following D107.2.

- H. The final plat tracing shall state in the plattor's text the ownership and maintenance responsibilities of the proposed reserves.
- I. Provisions shall be made for ownership and maintenance of the proposed reserves. The applicant shall either form a lot owners' association prior to recording the plat or shall submit a restrictive covenant stating when the association will be formed, when the reserve will be deeded to the association and who is to own and maintain the reserve prior to the association taking over those responsibilities. The plattor's text shall state, "Compliance with any platted restrictions and applicable restrictive covenants affecting said Reserves shall be binding on any owners, successors, heirs or assigns."
- J. For those reserves being platted for drainage purposes, the required covenant that provides for ownership and maintenance of the reserves, shall grant to the appropriate governing body the authority to maintain the drainage reserves in the event the owner(s) fail to do so. The covenant shall provide for the cost of such maintenance to be charged back to the owner(s) by the governing body.
- K. GIS has approved the street names.
- L. Since the subdivision is partially in a FEMA-regulated floodplain, the floodway certificate needs included in the plattor's text.
- M. <u>County Surveying</u> and MAPD requests review of a pdf prior to mylar submittal. Send to tricia.robello@sedgwick.gov and nstrahl@wichita.gov.
- N. Since this plat proposes the platting of narrow street right-of-way with adjacent 15-foot street, drainage and utility easements, a restrictive covenant shall be submitted which calls out restrictions for lot-owner use of these easements. Retaining walls and change of grade shall be prohibited within these easements as well as fences, earth berms and mass plantings.

The Subdivision Regulations limit cul-de-sac streets to 24 dwelling units accessed by a 32-foot narrow local residential street. A modification is needed for Vassar Circle (15 duplex lots).

### SUB2023-00015 – Sketch Plat of FALCON FALLS EAST $2^{\rm ND}$ ADDITION June 1, 2023 - Page 4

The Subdivision Committee may recommend a MODIFICATION/WAIVER of the design criteria in Article 7 of the Subdivision Regulations only if it finds that the strict application of the design criteria will create an unwarranted hardship, the proposed MODIFICATION/WAIVER is in harmony with the intended purpose of the Subdivision Regulations and the public safety and welfare will be protected.

- O. In accordance with the Backyard Drainage Policy, the plat shall state that "A master drainage plan has been developed for this plat. All drainage easements, rights-of-way, and reserves shall remain at established grades (unless modified with the approval of the City Engineer) and shall be unobstructed to allow for the conveyance of stormwater in accordance with the Stormwater Manual. The maintenance of all drainageways and drainage facilities in backyard drainage easements and reserves shall be the responsibility of the property owner and shall be enforced by the Homeowners' Association and be provided for in the Homeowners' Association covenants."
- P. In accordance with the Backyard Drainage Policy, a restrictive covenant shall be submitted stating: "A master drainage plan has been developed for this plat. All drainage easements, rights-of-way, and reserves shall remain at established grades (unless modified with the approval of the City Engineer) and shall be unobstructed to allow for the conveyance of stormwater in accordance with the Stormwater Manual. The maintenance of all drainageways and drainage facilities in backyard drainage easements and reserves shall be the responsibility of the property owner and shall be enforced by the Homeowners' Association and be provided for in the Homeowners' Association covenants. The property owner shall provide a copy of the Individual Lot Grading Plan and the Individual Lot Grading Plan Certificate pertaining to such owner's lot to any person installing a lawn, landscaping, fencing, or other improvements or structures and require them to maintain the grade levels shown on the Individual Lot Grading Plan Certificate."
- Q. The Wichita Bicycle Master Plan denotes a bicycle/pedestrian shared use path running northwesterly near the west property line. It is recommended that a public access easement be listed as a use permitted within Reserve B. The plattor's text shall state "The public access easement is hereby granted to the public as indicated for the construction and maintenance of a shared use pedestrian and bicycle path."
- R. The applicant has platted a 5-foot front building setback for Reserve C which represents an adjustment of the Zoning Code standard of 25 feet for the MF-18 Multi-Family District. The Subdivision Regulations permit the setback provisions to be modified by the plat upon the approval of the Planning Commission.
- S. Approval of this plat will require a waiver of the lot depth-to-width ratio of the Subdivision Regulations for Lots 25, and 31, Block A, and Lot 6, Block C. The Subdivision Regulations state that the maximum depth of all residential lots shall not exceed 2.5 times the width.
  - The Subdivision Committee may recommend a MODIFICATION/WAIVER of the design criteria in Article 7 of the Subdivision Regulations only if it finds that the strict application of the design criteria will create an unwarranted hardship, the proposed MODIFICATION/WAIVER is in harmony with the intended purpose of the Subdivision Regulations and the public safety and welfare will be protected.
- T. The Applicant is reminded that a platting binder is required with the final plat. Approval of this plat will be subject to submittal of this binder and any relevant conditions found by such a review.
- U. The applicant shall install or guarantee the installation of all utilities and facilities that are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Fire Code Official.)

# SUB2023-00015 – Sketch Plat of FALCON FALLS EAST $2^{\rm ND}$ ADDITION June 1, 2023 - Page 5

- V. The Register of Deeds requires all names to be printed beneath the signatures on the plat and any associated documents.
- W. Prior to development of the plat, the applicant is advised to meet with the United States Postal Service Growth Management Coordinator (Phone: (316) 946-4595) in order to receive mail delivery without delay, avoid unnecessary expense and determine the type of delivery and the tentative mailbox locations.
- X. The applicant is advised that various State and Federal requirements (specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Route 1, Box 317, Valley Center, KS 67147) for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- Y. The owner of the subdivision should note that any construction that results in earthwork activities that will disturb one acre or more of ground cover requires a Federal/State National Pollutant Discharge Elimination System Stormwater Discharge Permit from the Kansas Department of Health and Environment in Topeka. Also, for projects located within the City of Wichita, erosion and sediment control devices must be used on ALL projects. For projects outside of the City of Wichita, but within the Wichita metropolitan area, the owner should contact the appropriate governmental jurisdiction concerning erosion and sediment control device requirements.
- Z. Perimeter closure computations shall be submitted with the final plat tracing.
- AA. The applicant should check City or County GIS mapping to determine whether the location of any taxing district boundaries (e.g. school districts) crosses their property and plan accordingly to avoid unnecessary splitting of lots between taxing districts.
- BB. <u>Evergy</u> will need to request additional easements. Kevin Rieschick, Design Representative, will be the contact for this plat and can be contacted at (785) 508-2689. Any relocation or removal of existing service due to this plat will be at the applicant's expense.
- CC. A PDF of the recorded plat should be sent to <a href="mailto:kwilson@wichita.gov">kwilson@wichita.gov</a> and <a href="mailto:abias@wichita.gov">abias@wichita.gov</a>. Please provide AutoCAD detailing the final plat in digital format via email to City GIS staff (ARosas@wichita.gov) and County GIS staff (Jack.Joseph@sedgwick.gov).