


# Hydraflow Plan View



sws5\_RW

No. Lines: 11

04-23-2007

# Storm Sewer Summary Report

Line No.	Line ID	Flow rate (cfs)	Line size (in)	Line length (ft)	Invert EL Dn (ft)	Invert EL Up (ft)	Line slope (%)	HGL down (ft)	HGL up (ft)	Minor loss (ft)	HGL Junct (ft)	Dns line No.
1		27.30	48 c	83.5	1249.00	1249.07	0.084	1252.22	1252.25	0.05	1252.30	End
2		25.40	48 c	30.5	1249.07	1249.09	0.066	1252.31	1252.32	0.04	1252.36	1
3		23.50	48 c	194.2	1249.09	1249.25	0.082	1252.36	1252.41	0.11	1252.52	2
4		22.10	42 c	64.2	1249.75	1249.83	0.125	1252.52	1252.55	0.06	1252.60	3
5		22.10	42 c	318.0	1249.83	1250.21	0.120	1252.60	1252.76	0.13	1252.89	4
6		19.70	42 c	151.8	1250.21	1250.39	0.119	1252.91	1252.97	0.16	1253.13	5
7		17.10	36 c	151.6	1250.89	1251.07	0.119	1253.13	1253.25	0.08	1253.32	6
8		11.35	36 c	36.3	1251.07	1251.14	0.193	1253.41	1253.41	0.03	1253.44	7
9		5.60	24 c	140.0	1252.14	1252.56	0.300	1253.46	1253.60	0.09	1253.69	8
10		4.00	18 c	205.2	1253.06	1253.84	0.380	1253.91	1254.69	n/a	1254.87 i	9
11		2.10	15 c	208.2	1254.09	1254.88	0.380	1254.87	1255.49	n/a	1255.70 i	10

sws5_RW	Number of lines: 11	Run Date: 04-23-2007
---------	---------------------	----------------------

NOTES: c = cir; e = ellip; b = box; Return period = 2 Yrs. ; i - Inlet control.

# Inlet Report

Line No	Inlet ID	Q = CIA (cfs)	Q carry (cfs)	Q capt (cfs)	Q byp (cfs)	Junc type	Curb Inlet		Grate Inlet			Gutter						Inlet			Byp line No	
							Ht (in)	L (ft)	area (sqft)	L (ft)	W (ft)	So (ft/ft)	W (ft)	Sw (ft/ft)	Sx (ft/ft)	n	Depth (ft)	Spread (ft)	Depth (ft)	Spread (ft)		Depr (in)
1		1.90*	0.00	1.90	0.00	Curb	6.0	10.00	0.00	0.00	0.00	Sag	2.00	0.080	0.030	0.000	0.25	5.10	0.32	5.10	2.00	Off
2		1.90*	0.00	1.90	0.00	Curb	6.0	10.00	0.00	0.00	0.00	Sag	2.00	0.080	0.030	0.000	0.25	5.10	0.32	5.10	2.00	Off
3		1.40*	0.00	1.40	0.00	DrGrt	0.0	0.00	8.00	4.00	2.00	Sag	2.00	0.020	0.020	0.000	0.11	13.47	0.11	13.47	0.00	Off
4		0.00	0.00	0.00	0.00	MH	0.0	0.00	0.00	0.00	0.00	Sag	0.00	0.000	0.000	0.000	0.00	0.00	0.00	0.00	0.00	Off
5		2.40*	0.00	2.40	0.00	DrGrt	0.0	0.00	8.00	4.00	2.00	Sag	2.00	0.020	0.020	0.000	0.16	18.43	0.16	18.43	0.00	Off
6		2.60*	0.00	2.60	0.00	DrGrt	0.0	0.00	8.00	4.00	2.00	Sag	2.00	0.020	0.020	0.000	0.17	19.33	0.17	19.33	0.00	Off
7		5.75*	0.00	5.75	0.00	Curb	6.0	10.00	0.00	0.00	0.00	Sag	2.00	0.080	0.030	0.000	0.42	10.72	0.49	10.72	2.00	Off
8		5.75*	0.00	5.75	0.00	Curb	6.0	10.00	0.00	0.00	0.00	Sag	2.00	0.080	0.030	0.000	0.42	10.72	0.49	10.72	2.00	Off
9		1.60*	0.00	1.60	0.00	DrGrt	0.0	0.00	8.00	4.00	2.00	Sag	2.00	0.020	0.020	0.000	0.13	14.53	0.13	14.53	0.00	Off
10		1.90*	0.00	1.90	0.00	DrGrt	0.0	0.00	8.00	4.00	2.00	Sag	2.00	0.020	0.020	0.000	0.14	16.06	0.14	16.06	0.00	Off
11		2.10*	0.00	2.10	0.00	DrGrt	0.0	0.00	8.00	4.00	2.00	Sag	2.00	0.020	0.020	0.000	0.15	17.03	0.15	17.03	0.00	Off

sws5\_RW

Number of lines: 11

Run Date: 04-23-2007

NOTES: Inlet N-Values = 0.016 ; Intensity = 69.87 / (Inlet time + 13.10) ^ 0.87; Return period = 2 Yrs. ; \* Indicates Known Q added

# Hydraulic Grade Line Computations

Line	Size (in)	Q (cfs)	Downstream								Len (ft)	Upstream								Check		JL coeff (K)	Minor loss (ft)
			Invert elev (ft)	HGL elev (ft)	Depth (ft)	Area (sqft)	Vel (ft/s)	Vel head (ft)	EGL elev (ft)	Sf (%)		Invert elev (ft)	HGL elev (ft)	Depth (ft)	Area (sqft)	Vel (ft/s)	Vel head (ft)	EGL elev (ft)	Sf (%)	Ave Sf (%)	Enrgy loss (ft)		
1	48	27.30	1249.00	1252.22	3.22	10.84	2.52	0.10	1252.32	0.037	83.5	1249.07	1252.25	3.18	10.71	2.55	0.10	1252.35	0.038	0.038	0.032	0.50	0.05
2	48	25.40	1249.07	1252.31	3.24	10.91	2.33	0.08	1252.40	0.032	30.5	1249.09	1252.32	3.23	10.87	2.34	0.08	1252.41	0.032	0.032	0.010	0.50	0.04
3	48	23.50	1249.09	1252.36	3.27	11.01	2.14	0.07	1252.43	0.027	194	1249.25	1252.41	3.16	10.64	2.21	0.08	1252.49	0.029	0.028	0.054	1.50	0.11
4	42	22.10	1249.75	1252.52	2.77	8.17	2.70	0.11	1252.64	0.052	64.2	1249.83	1252.55	2.72	8.02	2.76	0.12	1252.67	0.054	0.053	0.034	0.47	0.06
5	42	22.10	1249.83	1252.60	2.77	8.18	2.70	0.11	1252.72	0.051	318	1250.21	1252.76	2.55	7.52	2.94	0.13	1252.90	0.062	0.057	0.180	0.97	0.13
6	42	19.70	1250.21	1252.91	2.70	7.96	2.47	0.10	1253.00	0.043	152	1250.39	1252.97	2.58	7.61	2.59	0.10	1253.08	0.048	0.046	0.069	1.50	0.16
7	36	17.10	1250.89	1253.13	2.24	5.65	3.02	0.14	1253.27	0.080	152	1251.07	1253.25	2.18	5.49	3.11	0.15	1253.40	0.086	0.083	0.126	0.50	0.08
8	36	11.35	1251.07	1253.41	2.34	5.91	1.92	0.06	1253.47	0.032	36.3	1251.14	1253.41	2.27	5.75	1.97	0.06	1253.47	0.034	0.033	0.012	0.50	0.03
9	24	5.60	1252.14	1253.46	1.32	2.19	2.56	0.10	1253.56	0.104	140	1252.56	1253.60	1.04	1.66	3.38	0.18	1253.78	0.213	0.158	0.222	0.50	0.09
10	18	4.00	1253.06	1253.91	0.85*	1.04	3.85	0.23	1254.14	n/a	205	1253.84	1254.69	0.85	1.04	3.85	0.23	1254.92i	n/a	n/a	0.549	1.50	n/a
11	15	2.10	1254.09	1254.87	0.78	0.80	2.62	0.11	1254.97	n/a	208	1254.88	1255.49	0.60	0.59	3.57	0.20	1255.68i	n/a	n/a	0.511	1.00	n/a

sws5\_RW

Number of lines: 11

Run Date: 04-23-2007

Notes: \* Normal depth assumed.

# Storm Sewer Profile

Elev. (ft)

