

THE CITY OF WICHITA

OFFICE OF DEPARTMENT OF ENGINEERING DATE April 30, 1981

TO Jack Galbraith, Chief Planner

FROM Chris Breitenstein, Drainage & Flood Control Engineer

SUBJECT Subdivision Agenda - April 30
Approval of Plans OR
Approval Subject to Various
Stipulations

Cedar Lakes Plaza 2nd Addition--Site Grading Plan - Entire lot
should be graded to above 171.6, such that it will drain
when Harry Street is improved to arterial standards;
otherwise there needs to be a private storm water sewer.


Willo-Esque 5th Addition

Northwest Village 3rd Addition

Twin Oaks Addition - Site Grading Plan should be submitted to
Engineering before obtaining building permit.

Green Addition

Caliendo 7th Addition


Chris Breitenstein
Drainage & Flood Control
Engineer

CJB:md

cc: Louise Olivarez
Mike Lindebak