

Pre. Sub Mar. 28, 1985

Water

Item

Project

1. Vac. Access Control on Tyler Ct. - no problem
2. Sherwood Acres Mobile Home Park - Water goes E from Minneapolis to approx. 146' E. of E Minneapolis
3. Midtown Third Addition - 6" water in Water St. Access must be maintained along Water St. Park Elem. School has service from Water St. Is Lot 5 - 40x433?
4. Inwood Addition - No water in 36th or 34th at this time. There is a project for 36 St. (Cometara Office Center 81758) and a project for 34th St. (8175); neither have been let. No project set up for Inwood Area Item A - extend water.
5. Deerwood Addition - Existing 24" PCSC Water Main in Webb Rd.
6. Andersen Investment Third - Area served
7. Batson Industrial Second - Mnd Petition for Water extension
8. Lot 2 Block 3 Riverside Ranch Second - No problem
9. Tollross Co. Utility Esmt. - No problem
10. Lot 3 & 4 Sherwood - No water in Esmt.