



WICHITA, KANSAS

ADDENDUM NO. 2
TO THE BID FORM 240171

Cowskin Air Release Valves and Lift Station Improvements
(South of 31st Street South, west of Meridian)
468-2022-040654/53202120/S0021

TO BE BID: August 9, 2024

The following changes and additions shall be made to the plans and proposal.

1. **Airport Property Access.** Airport Fire/Safety Dispatch must be notified at 316-946-4740 prior to any work on airport property.
2. **Lift Station 60 Flow.** Flow rates from Lift Station 60 are not available. Only one sink and toilet are connected. Service may be shut down for up to 24 hours.
3. **Force Main Fittings Material.** **Schedule 80 PVC is an acceptable material for force main fittings.**

Each bidder is required to acknowledge receipt of this Addendum by his signature affixed hereto and to file same with and attached to his bid. Any Bid Proposal that is returned without all addenda signed and included in the Proposal shall be considered an invalid Proposal.

August 7, 2024

Paul Gunzelman, P.E.
City Engineer

Date _____

Signature of Bidder

BIDDER: _____
(print or type name of firm)

ADDRESS: _____

AUTHORIZED AGENT: _____
(Signature)

(print or type name of authorized agent)