



10-25-2024

Brewer Community Center.

COW # 2023-026216 PPW.

McCullough Excavation.

Looking West from Water Vault
along Line 1. Sta 0+00 - 8" TAP at
top of Photo.

16" HDPE Casing Pipe =
28'-9 1/2" in length.

Water Pipe = 8" RJPVC & DICL.

This is a "Down & Under" due to
conflict with an 8" HDPE Pipe
(Black with Purple Stripes) = North
Industrial Corridor Site = Waste
Water Force Main.

New Water Pipe is now 2' below
Waste Water Pipe.

This location is below N. Wabash
Ave.