



WICHITA

Transmittal Form Chain of Custody New Main/Construction Water Quality Report

2 4 of 2 5

Wichita Public Works & Utilities

Production and Pumping Division, 1800 Museum Blvd.
Wichita Municipal Water & Wastewater Laboratory E-60603
Phone # 316-269-4770/4771
Fax # 316-858-7780

APPROVED BY: Cornelius L. Blaylock C.L.B

OF SAMPLES: 1 RECEIPT #: 296601

Project Location: Brewer Community Center 1326 E. 16th St

Contractor: McCullough Exc

Project Number: 2023-026216 ppw

Contractor phone #: 316-634-2199

OCA Number: 185407

Contractor fax #:

Sample Collector: Qebny

Contractor email: 1206@mcculloughexcavation.com

LPowell@baughmanco.com

Items in gray are for Lab Use only

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl ₂	Comment
1/23/25	10:05 AM	Riser F-L in Bldg 10+00 - 16+82.88	EF 0000	Fail	3.85 @ 11:18 JJC	Bacteria present

For Private Project use only
one sample per sheet

- PLEASE RETURN EMPTY BOTTLES TO LABORATORY
- SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature: [Signature]

Date & time 1/23/25 11:10

CUSTODY RECORD		DATE	TIME		DATE	TIME
Relinquished by:	<u>[Signature]</u>	1/23/25	10:05	Received by:	<u>[Signature]</u>	1/23/25 11:13
Print Name:	<u>126001</u>			Print Name:	<u>Jose Covarrubias</u>	
Relinquished by:				Received by:		
Print Name:				Print Name:		

I, the Witness, have personally seen this sample collected at the date and time recorded above.

To be filled out by the witness only:

Inspection company: Baughman Company Date: 1-23-25 Time: 10:11 AM

Signature: Larry Powell Printed Name: Larry Powell

Results Submitted by: [Signature] Date: 1-24/25