

WATER LINE PRESSURE TEST

PROJECT: PRIVATE WATER DISTRIBUTION SYSTEM IMPROVEMENTS TO SERVE
BREWER COMMUNITY CENTER

CITY NO.: 2023-026216 PPW BAUGHMAN PROJECT NO.: 24-08-E869

UTILITY CONTRACTOR: McCullough Excavation

PRESSURE TEST PERFORMED BY: Gabriel (McCullough Excavation)

DATE: 1/9/2024 PRESSURE TEST SPEC: 200 psi

WATERLINE I.D.: FP Line 1 STA 0+02 to Fire Riser

PRESSURE GAUGE LOCATION: Fire Riser in Building

BEGIN TEST PRESSURE: 210 psi TIME: 12:00 PM

END TEST PRESSURE: 209 psi TIME: 2:00 PM

PRESSURE DIFFERENCE: 1 psi

PRESSURE GAUGE: Dropped to 0 psi after water pressure was released. Good.

PRESSURE TEST RESULT: **PASS**

PRESSURE TEST WITNESSED BY: Beau Gibler

Beau Gibler - Baughman Company, P.A.