

DAILY CONSTRUCTION INSPECTION REPORT

Date: 2 Feb 26

City Project Number: 2025-000925 PPD (H+W Storage)

KEM Project Number: 25-197

Contractor: NCUAK

Inspector: Eric Miner

Weather: 29° + Fair

Construction Activities:

START @ STA 0+00 install (1) 18" END
Section. (Line 1)

install 24.73 LF of 18" RCP @ a 1.0% grade.

to ~~XXXX~~ STA 24.73 install 18" RCP END section

~~End Section @ this point~~