

DAILY CONSTRUCTION INSPECTION REPORT

Date: 23 MAR 26

City Project Number: 2025-007659PPW (Ferrolks 2nd ADD)

KEM Project Numbers: 26-052

Contractor: Fire Protection Services

Inspector: Eric Miner

Weather: 39° + Sunny

Construction Activities: Install Test station/ANODE. Tracer

wire taped to top of main and

Pressure test scheduled for today.

- Pea Gravel WAS~~IS~~ installed @
weep hole on F/H

* Pressure Test *

START: 170 psi

END: 167 psi PASS