

Certification of Conformance

Date: September 25, 2025

<u>Contractor:</u>	McCullough Excavation
<u>Your Order No.:</u>	
<u>Project Name:</u>	South Central Kansas Regional Psychiatric
<u>Distributor:</u>	Mountainland Supply Company
<u>Branch/City/State:</u>	Wichita, KS

The product(s) covered by this certification were manufactured in the USA in accordance with the specification(s) noted below.

1000' - 8" Cast Iron Outside Diameter Pressure Pipe per ANSI/AWWA C900

60' – 8" Cast Iron Outside Diameter Pressure Pipe per ANSI/AWWA C900/RJIB

1740' – 4" Cast Iron Outside Diameter Pressure Pipe per ANSI/AWWA C900

60' – 4" Cast Iron Outside Diameter Pressure Pipe per ANSI/AWWA C900/RJ

1. All Gaskets per ASTM F477
2. All Potable Water Pipe listed to ANSI/NSF Standard 61
3. PVC cell classification 12454 as defined in ASTM D1784

Sincerely,

Chris Jessup