



Transmittal Form Chain of Custody New Main/Construction Water Quality Report

2 3 of 2 5

Wichita Public Works & Utilities

Production and Pumping Division, 1800 Museum Blvd.
Wichita Municipal Water & Wastewater Laboratory E-60603
Phone # 316-269-4770/4771
Fax # 316-858-7780

APPROVED BY: Cornelius L. Blaylock C.L.B.

OF SAMPLES: 1 RECEIPT #: E66166

Project Location: 2020 N Rock Rd Contractor: McCullough Exc
Project Number: 2025-031899 PPW Contractor phone #: 316-634-2199
OCA Number: 185407 Contractor fax #:
Sample Collector: C. Blaylock Contractor email: ~~blaylock@cityofwichita.com~~

Rob@mccloughexcavation.com
C. Blaylock@mccloughexcavation.com
JPRIDDE@BAUGHMAN.CO.COM

Items in gray are for Lab Use only

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl ₂	Comment
4/20/26	11:25	F.L 16+00.00 - 16+69.19	E602130	PASS	3.07 13.99 MGD	

For Private Project use only
one sample per sheet

E-Mailed

APR 21 2026

PWU/Prod & Pump/WWW

- PLEASE RETURN EMPTY BOTTLES TO LABORATORY
- SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature: [Signature]

Date & time 4/20/26 1:30

CUSTODY RECORD	DATE	TIME	DATE	TIME
Relinquished by: [Signature]	4/20/26	11:25	Received by: [Signature]	4/20/26 13:30
Print Name: C. Blaylock			Print Name: MD Searz	
Relinquished by:			Received by:	
Print Name:			Print Name:	

I, the Witness, have personally seen this sample collected at the date and time recorded above.

To be filled out by the witness only:

Inspection company: BAUGHMAN CO. Date: 20 APRIL 26 Time: 11:25 A

Signature: [Signature] Printed Name: JEFF BAUMLE

Results Submitted by: [Signature] Date: 4/20/26