



BAUGHMAN COMPANY, P.A.

ENGINEERING, SURVEYING & PLANNING

316/262-7271 FAX 316/262-0149 WICHITA, KANSAS 67211

WATER LINE PRESSURE TEST

Project Description:	Fire Protection Line to serve	Date:	13-Apr-2026
	The Cheesecake Factory	Inspector:	Jeff Priddle
	2020 N. Rock Rd.	Contractor:	McCullough Excavation
Project No.:	2025-031899 PPW	Superintendent:	Rob Gray
		Engineer:	Scott Evans - MKEC
		Baughman Job No.:	26-02-E390

PRESSURE TEST SPEC:

☒ X

200 PSI

☐ 150 PSI

WATERLINE I.D.: Fire Service 6" STA 10+01.5 to STA 10+72

PRESSURE GAUGE LOCATION: Attached to Vertical Riser Flange

BEGIN TEST PRESSURE: 218 psi TIME: 10:10 AM

END TEST PRESSURE: 218 psi TIME: 12:10 PM

PRESSURE DIFFERENCE: 0 psi

PRESSURE GAUGE ZEROED OUT:

☒ X

YES

☐ NO

Notes: _____

PRESSURE TEST RESULT: **PASS**

PRESSURE TEST WITNESSED BY:

Jeff Priddle - Baughman Company, P.A.