

NOTED CHANGES TO THE PLANS OR SCOPE

Date: 4/15/26

Cadillac Lake 2nd Addition -

Project: 2824 N. Maize Rd.

COW Number: 2025-029081 PPW

Contractor: K&B Dirtworks

Baughman Number: 26-02-E403

Superintendent: Scott Bratcher

Inspector: Beau Gibler

No.	Location/Station	Item Changed	Description / Reason
1	Line 1, Sta 3+16	Valve	Added anchored valve, per Paul McDonald (Engineer - Baughman Co.).
2	Line 2, Sta 2+41, Line 4, Sta 0+62, Line 5, Sta 0+37	Special Anchored Valve	Changed to anchored coupling at valve, Per Paul McDonald (Engineer - Baughman Co.)
3	Line 1, Sta 0+1.5 to 3+64	Pipe Installation	Water Pipe installed per Directional Bore, to avoid existing utilities. Certa-Lok pipe used.
4	Drive way entrance from Maize Rd, See as-built sheet 4A	Existing Blowoff Removal	Per request of General Contractor, existing blowoff valve assembly removed and piping to tap valve removed. Tapping valve capped in-place.
5	Line 4, Sta 0+02	Added 2 - 45° Bends	Added bends to adjust for vertical alignment, bends Mega lugged to Tee of Line 1.