DAILY CONSTRUCTION INSPECTION REPORT

Date: 24 MAR 26

City Project Number: 2025-009916 PPW (Community Crisis Center)

KEM Project Numbers: 26-053

Contractor: McCollough

Inspector: **Eric Miner**

Weather: 67° + Sunny

Construction Activities:

* City TAP *
install 8"x6" tapping sleeve and valve.
(C-900) install [redacted] 6" pipe to ductile iron (5' out of bldg) core drill through floor and install 6" bldg connection
All Thrust Blocks were poured and look great. [redacted]