DAILY CONSTRUCTION INSPECTION REPORT

Date: 26MAR26

City Project Number: 2025-009916 PPW (Community Crisis Center)

KEM Project Numbers: 26-053

Contractor: McCullough

Inspector: **Eric Miner**

Weather: 67° + Sunny

Construction Activities:

* Pressure Test *

START @ 8:00 am @ 210 PSI

END @ 10:00 am @ 209 PSI

Lost 1 PSI PASS