BAUGHMAN COMPANY, P.A.
ENGINEERING, SURVEYING & PLANNING
316/262-7271 FAX 316/262-0149 WICHITA, KANSAS 67211

NOTED CHANGES TO THE PLAN OR SCOPE

		Date:	14-May-2026
Project Description:	Maple St. Apartments	Inspector:	Jeff Priddle
	721 W. Maple St	Contractor:	Carr's Plumbing and Maintenance
Project No.:	2025-013466 PPW	Superintendent:	Lee Roush
		Engineer:	Baughman Company, P.A.
		Baughman Job No.:	26-04-E483

ITEM #1: PIPE FROM RISER'S 90° VERTICAL BEND TO 5' OUTSIDE BUILDING :

Vertical Riser Pipes in all three apartment buildings, from 90° vertical bend = 2" CPVC Spears FlameGuard pipe. From 90° vertical bend to valve = 2" CPVC Sch. 80 pipe.

ITEM #2: WATER METER LOCATION:

City of Wichita moved Water Meter location from east side of sidewalk to west side of sidewalk.