DAILY CONSTRUCTION INSPECTION REPORT

Date: 2/14/2025

City Project Number: 2024-006705PPW (540300980) Killarney Plaza 2nd Duplexes.

KEM Proj. Number: 23-175

Contractor: McCullough Exc.

Inspector: LARRY GANN

Weather: Cold!!! 28° cloudy

Construction Activities: 2 hour test on water line. - opening valve slowly START TEST AT 12:10 AT 164 psi. — LOST 1 psi in 2 hours.