


CONSTRUCTION PLANS FOR
LATERAL 24, MAIN 12
 OF THE
SOUTHWEST INTERCEPTOR SEWER
 IN
THE CITY OF WICHITA,
 SEDGWICK COUNTY, KANSAS
 MICHAEL E. LINDEBAK, P.E. - CITY ENGINEER



LOCATION MAP

INDEX OF SHEETS


SHEET NO. 1	TITLE SHEET
SHEET NO. 2	KEY MAP
SHEET NO. 3	PLAN
SHEET NO. 4-8	PLAN/PROFILE
SHEET NO. 9	TYPE "D" MANHOLE DETAILS
SHEET NO. 10	TYPE "C" MANHOLE DETAILS
SHEET NO. 11	TYPE "D" MANHOLE DETAILS
SHEET NO. 12	FRAME & COVER DETAIL
SHEET NO. 13	RISE DETAIL

AS BUILT
 RDL
 2-88


WICHITA PROJECT NO. 468-76-245-81733-000-000-001

AUGUST, 1987


PLANS PREPARED BY
PROFESSIONAL ENGINEERING CONSULTANTS, P.A.
 ENGINEERS
 WICHITA, KANSAS



WOODBRIDGE 2TH ADDITION TO WICHITA, SEDGWICK COUNTY, KANSAS



2.2. = SAWYER CENTER
B.2.1. = BUILDING SETBACK LINE
AREA = 1701.003 M.2.1.
AND WIDE ROAD
150 FEET WEST OF INTERSECTION 51ST ST.
BENCH MARK - CHISELED "21" AT N.E. COR. OF HEADWALL
SCALE: 1" = 100'
O = IRON SET




KEY MAP

Benefit District

Lots 1 through 38 inclusive and
Lots 62 and 66, Block 5, Woodbridge
2th Addition;

Lots 2 through 10 inclusive and
Lots 18 and 19, Block 4, Country
Village Addition



- GENERAL NOTES
1. ALL CONSTRUCTION AND MATERIALS TO COMPLY WITH CITY OF WICHITA SPECIFICATIONS AND STANDARDS.
 2. ALL ELEVATIONS SHOWN ARE CITY OF WICHITA DATUM (1928-1187.4 = CITY DATUM).
 3. THE CONTRACTOR SHALL LIMIT THE EXTENT OF TRENCH TO REMAIN OPEN OVERNIGHT AND WEEKENDS TO LESS THAN 20 FEET.
 4. AT LEAST 48 HOURS PRIOR TO BEGINNING EXCAVATION, IF REQUIRED, (EXCLUDING WEEKENDS AND HOLIDAYS), THE CONTRACTOR SHALL CONTACT THE KANSAS ONE-CALL SYSTEM, A UTILITY LOCATION SERVICE, AT (913) 887-5870 TO REQUEST THE FOLLOWING UTILITY COMPANIES TO LOCATE ANY EXISTING LINES WITHIN THE PROJECT AREA: GAS SERVICE COMPANY, K.G.B.E., THE WICHITA WATER DEPARTMENT, AIR CAPITAL CABLEVISION, AND THE TELEPHONE COMPANY.
 5. UNDERGROUND UTILITY SERVICE LINES AND OVERHEAD UTILITY POLE LINES ARE TO BE ADJUSTED AS NECESSARY BY OTHERS PRIOR TO CONSTRUCTION UNLESS THE PLANS SPECIFICALLY CALL FOR THEIR ADJUSTMENT BY THE CONTRACTOR OR UNLESS THE PLANS SPECIFICALLY IDENTIFY A UTILITY TO BE ADJUSTED BY ITS OWNER DURING CONSTRUCTION. EXISTING UTILITIES AND THEIR LOCATION AS SHOWN ON THE PLANS REPRESENT THE BEST INFORMATION OBTAINABLE FOR DESIGN. THE CONTRACTOR SHALL BE REQUIRED TO WORK AROUND EXISTING UTILITIES WITHIN THE RIGHT-OF-WAY WHICH DO NOT CONFLICT WITH PROPOSED CONSTRUCTION.
 6. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PRESERVING PROPERTY INTERESTS. THE CONTRACTOR SHALL BE REQUIRED TO RE-ESTABLISH ANY PROPERTY LINES WHICH ARE DAMAGED OR DESTROYED BY HIS CONSTRUCTION OPERATIONS. SUCH WORKS SHALL BE RE-ESTABLISHED BY A LICENSED LAND SURVEYOR OR A LICENSED PROFESSIONAL ENGINEER IN ACCORDANCE WITH KANSAS STATE LAW. ALL COSTS FOR THIS WORK SHALL BE SUBORDINARY TO THE OTHER ITEMS OF WORK.
 7. CONTRACTOR SHALL PROVIDE POSITIVE DRAINAGE AWAY FROM ALL MANHOLE COVERS.
 8. CONTRACTOR SHALL GRADE THE EASEMENTS TO THE ELEVATIONS SHOWN ON THE EASEMENT GRADING PLAN. COSTS FOR EASEMENT GRADING SHALL BE SUBORDINARY TO THE OTHER ITEMS OF WORK.
 9. UNLESS OTHERWISE SPECIFIED ON THE PLANS MANHOLES MAY BE TYPE "B", "C", OR "D". MANHOLES SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS AND THE STANDARD DETAIL DRAWINGS.
 10. RISER LOCATION SHALL INSTALL TEE SADDLES AND RISERS AS INDICATED ON THE DETAIL DRAWINGS.

RISER LOCATION TABLE			
TEE SADDLE LOCATION			
LINE NO.	STATION	LOT NO.	DIRECTION (L.F.)
1	0+15	2	L.F.
1	0+20	6	R.F.
1	0+25	2	L.F.
1	0+30	7	R.F.
1	0+35	2	L.F.
1	0+40	8	R.F.
1	0+45	2	L.F.
1	0+50	9	R.F.
1	0+55	2	L.F.
1	0+60	10	R.F.
1	0+65	2	L.F.
1	0+70	11	R.F.
1	0+75	2	L.F.
1	0+80	12	R.F.
1	0+85	2	L.F.
1	0+90	13	R.F.
1	0+95	2	L.F.
1	1+00	14	R.F.
1	1+05	2	L.F.
1	1+10	15	R.F.
1	1+15	2	L.F.
1	1+20	16	R.F.
1	1+25	2	L.F.
1	1+30	17	R.F.
1	1+35	2	L.F.
1	1+40	18	R.F.
1	1+45	2	L.F.
1	1+50	19	R.F.
1	1+55	2	L.F.
1	1+60	20	R.F.
1	1+65	2	L.F.
1	1+70	21	R.F.
1	1+75	2	L.F.
1	1+80	22	R.F.
1	1+85	2	L.F.
1	1+90	23	R.F.
1	1+95	2	L.F.
1	2+00	24	R.F.

* Country Village Addition
* All other locations are in Woodbridge 2th Addition


KEY MAP



SOUTHWEST INTERCEPT CENTER
LATERAL 24" MAIN IS OF THE

PROFESSIONAL ENGINEERING CONSULTANTS, P.A.
WICHITA, KANSAS
ENGINEERS

Designed by: CRY, WDS
Job No.: 24-87128-4
Date: AUGUST, 1987
Sheet: 5 of 13

Michael D. Schoenberger
Professional Engineer
No. 0778
KANSAS
LICENSED







LATERAL 24, MAIN 12 OF THE
SOUTHWEST INTERCEPT SYSTEM

PROFESSIONAL ENGINEERING CONSULTANTS, P.A.

WRIGHT, K. K. 1983.


ed by CR, Mob Job No. 24 875-4

1997 : 1998 : 1999 : 2000 : 2001 : 2002 : 2003 : 2004 : 2005 : 2006 : 2007 : 2008 : 2009 : 2010 : 2011 : 2012 : 2013 : 2014 : 2015 : 2016 : 2017 : 2018 : 2019 : 2020 : 2021 : 2022 : 2023 : 2024 : 2025 : 2026 : 2027 : 2028 : 2029 : 2030 : 2031 : 2032 : 2033 : 2034 : 2035 : 2036 : 2037 : 2038 : 2039 : 2040 : 2041 : 2042 : 2043 : 2044 : 2045 : 2046 : 2047 : 2048 : 2049 : 2050 : 2051 : 2052 : 2053 : 2054 : 2055 : 2056 : 2057 : 2058 : 2059 : 2060 : 2061 : 2062 : 2063 : 2064 : 2065 : 2066 : 2067 : 2068 : 2069 : 2070 : 2071 : 2072 : 2073 : 2074 : 2075 : 2076 : 2077 : 2078 : 2079 : 2080 : 2081 : 2082 : 2083 : 2084 : 2085 : 2086 : 2087 : 2088 : 2089 : 2090 : 2091 : 2092 : 2093 : 2094 : 2095 : 2096 : 2097 : 2098 : 2099 : 2100 : 2101 : 2102 : 2103 : 2104 : 2105 : 2106 : 2107 : 2108 : 2109 : 2110 : 2111 : 2112 : 2113 : 2114 : 2115 : 2116 : 2117 : 2118 : 2119 : 2120 : 2121 : 2122 : 2123 : 2124 : 2125 : 2126 : 2127 : 2128 : 2129 : 2130 : 2131 : 2132 : 2133 : 2134 : 2135 : 2136 : 2137 : 2138 : 2139 : 2140 : 2141 : 2142 : 2143 : 2144 : 2145 : 2146 : 2147 : 2148 : 2149 : 2150 : 2151 : 2152 : 2153 : 2154 : 2155 : 2156 : 2157 : 2158 : 2159 : 2160 : 2161 : 2162 : 2163 : 2164 : 2165 : 2166 : 2167 : 2168 : 2169 : 2170 : 2171 : 2172 : 2173 : 2174 : 2175 : 2176 : 2177 : 2178 : 2179 : 2180 : 2181 : 2182 : 2183 : 2184 : 2185 : 2186 : 2187 : 2188 : 2189 : 2190 : 2191 : 2192 : 2193 : 2194 : 2195 : 2196 : 2197 : 2198 : 2199 : 2200 : 2201 : 2202 : 2203 : 2204 : 2205 : 2206 : 2207 : 2208 : 2209 : 2210 : 2211 : 2212 : 2213 : 2214 : 2215 : 2216 : 2217 : 2218 : 2219 : 2220 : 2221 : 2222 : 2223 : 2224 : 2225 : 2226 : 2227 : 2228 : 2229 : 2230 : 2231 : 2232 : 2233 : 2234 : 2235 : 2236 : 2237 : 2238 : 2239 : 2240 : 2241 : 2242 : 2243 : 2244 : 2245 : 2246 : 2247 : 2248 : 2249 : 2250 : 2251 : 2252 : 2253 : 2254 : 2255 : 2256 : 2257 : 2258 : 2259 : 2260 : 2261 : 2262 : 2263 : 2264 : 2265 : 2266 : 2267 : 2268 : 2269 : 2270 : 2271 : 2272 : 2273 : 2274 : 2275 : 2276 : 2277 : 2278 : 2279 : 2280 : 2281 : 2282 : 2283 : 2284 : 2285 : 2286 : 2287 : 2288 : 2289 : 2290 : 2291 : 2292 : 2293 : 2294 : 2295 : 2296 : 2297 : 2298 : 2299 : 2300 : 2301 : 2302 : 2303 : 2304 : 2305 : 2306 : 2307 : 2308 : 2309 : 2310 : 2311 : 2312 : 2313 : 2314 : 2315 : 2316 : 2317 : 2318 : 2319 : 2320 : 2321 : 2322 : 2323 : 2324 : 2325 : 2326 : 2327 : 2328 : 2329 : 2330 : 2331 : 2332 : 2333 : 2334 : 2335 : 2336 : 2337 : 2338 : 2339 : 2340 : 2341 : 2342 : 2343 : 2344 : 2345 : 2346 : 2347 : 2348 : 2349 : 2350 : 2351 : 2352 : 2353 : 2354 : 2355 : 2356 : 2357 : 2358 : 2359 : 2360 : 2361 : 2362 : 2363 : 2364 : 2365 : 2366 : 2367 : 2368 : 2369 : 2370 : 2371 : 2372 : 2373 : 2374 : 2375 : 2376 : 2377 : 2378 : 2379 : 2380 : 2381 : 2382 : 2383 : 2384 : 2385 : 2386 : 2387 : 2388 : 2389 : 2390 : 2391 : 2392 : 2393 : 2394 : 2395 : 2396 : 2397 : 2398 : 2399 : 2400 : 2401 : 2402 : 2403 : 2404 : 2405 : 2406 : 2407 : 2408 : 2409 : 2410 : 2411 : 2412 : 2413 : 2414 : 2415 : 2416 : 2417 : 2418 : 2419 : 2420 : 2421 : 2422 : 2423 : 2424 : 2425 : 2426 : 2427 : 2428 : 2429 : 2430 : 2431 : 2432 : 2433 : 2434 : 2435 : 2436 : 2437 : 2438 : 2439 : 2440 : 2441 : 2442 : 2443 : 2444 : 2445 : 2446 : 2447 : 2448 : 2449 : 2450 : 2451 : 2452 : 2453 : 2454 : 2455 : 2456 : 2457 : 2458 : 2459 : 2460 : 2461 : 2462 : 2463 : 2464 : 2465 : 2466 : 2467 : 2468 : 2469 : 2470 : 2471 : 2472 : 2473 : 2474 : 2475 : 2476 : 2477 : 2478 : 2479 : 2480 : 2481 : 2482 : 2483 : 2484 : 2485 : 2486 : 2487 : 2488 : 2489 : 2490 : 2491 : 2492 : 2493 : 2494 : 2495 : 2496 : 2497 : 2498 : 2499 : 2500 : 2501 : 2502 : 2503 : 2504 : 2505 : 2506 : 2507 : 2508 : 2509 : 2510 : 2511 : 2512 : 2513 : 2514 : 2515 : 2516 : 2517 : 2518 : 2519 : 2520 : 2521 : 2522 : 2523 : 2524 : 2525 : 2526 : 2527 : 2528 : 2529 : 2530 : 2531 : 2532 : 2533 : 2534 : 2535 : 2536 : 2537 : 2538 : 2539 : 2540 : 2541 : 2542 : 2543 : 2544 : 2545 : 2546 : 2547 : 2548 : 2549 : 2550 : 2551 : 2552 : 2553 : 2554 : 2555 : 2556 : 2557 : 2558 : 2559 : 2560 : 2561 : 2562 : 2563 : 2564 : 2565 : 2566 : 2567 : 2568 : 2569 : 2570 : 2571 : 2572 : 2573 : 2574 : 2575 : 2576 : 2577 : 2578 : 2579 : 2580 : 2581 : 2582 : 2583 : 2584 : 2585 : 2586 : 2587 : 2588 : 2589 : 2590 : 2591 : 2592 : 2593 : 2594 : 2595 : 2596 : 2597 : 2598 : 2599 : 2600 : 2601 : 2602 : 2603 : 2604 : 2605 : 2606 : 2607 : 2608 : 2609 : 2610 : 2611 : 2612 : 2613 : 2614 : 2615 : 2616 : 2617 : 2618 : 2619 : 2620 : 2621 : 2622 : 2623 : 2624 : 2625 : 2626 : 2627 : 2628 : 2629 : 2630 : 2631 : 2632 : 2633 : 2634 : 2635 : 2636 : 2637 : 2638 : 2639 : 2640 : 2641 : 2642 : 2643 : 2644 : 2645 : 2646 : 2647 : 2648 : 2649 : 2650 : 2651 : 2652 : 2653 : 2654 : 2655 : 2656 : 2657 : 2658 : 2659 : 2660 : 2661 : 2662 : 2663 : 2664 : 2665 : 2666 : 2667 : 2668 : 2669 : 2670 : 2671 : 2672 : 2673 : 2674 : 2675 : 2676 : 2677 : 2678 : 26



BM - Chiseled "B" on East back of curb Pine Grove at Conc. joint approx. 45' North of hedge row at North side of Woodbridge 5th Addition. Elev. = 165.55

LINE NO. 1






LINE NO. 1


LATERAL 24" MAIN 12" OF THE SOUTHWEST INTERSECTION

PROFESSIONAL ENGINEERING CONSULTANTS, P.A.





Sheet 5/13





RM - South headball on fire hydrant at Northeast corner of Parkridge & Parkridge Ct. (3rd St. South of 2nd St. North on East side of Parkridge) Elev. +162.60

LINE NO. 2







LINE NO. 2

LATERAL 24" MAIN 12" OF THE
 SOUTHWEST INTERSECTION SEWER

WILLIAM L. SCHWARTZ, P.E., CITY ENGINEER
 CITY OF KANSAS, PROJECT NO. 418 TC 4-10721-100 001

PROFESSIONAL ENGINEERING CONSULTANTS, P.A.
 ENGINEERS
 1000 N. 10th St., Suite 100, Topeka, KS 66606
 Prepared By: GRC, M.D.
 Drawn By: JMA
 Date: August, 1987





LINE NO. 3 AND LINE NO. 4

LATERAL 24" MAIN 12" OF THE SOUTHWEST INTERCEPTOR SEWER

PROFESSIONAL ENGINEERING CONSULTANTS, P.C.

ENGINEERS

WICHITA, KANSAS

Des. & Prep. By: CLY. MBS


Job No. 34-P-77-1

Drawn By: JMB


Date: AUGUST 1978

Sheet 8 of 13


SEWER APPURTENANCES DETAILS ADOPTED AS STANDARD DESIGN BY CITY OF WICHITA




TYPE P
STANDARD MANHOLE



TYPE P
INSIDE DROP MANHOLE



TYPE P
OUTSIDE DROP MANHOLE



SECTION X
(TYPICAL)

GENERAL NOTES

1. ALL PRECAST CONCRETE MANHOLE SECTIONS SHALL CONFORM TO THE LATEST REVISION OF A.S.T.M. C478 AS MODIFIED BY THE SPECIFICATIONS.
2. NON-SHRINK GROUT SHALL BE NON-METALLIC TYPE.
3. APPROVED FLEXIBLE WATERSTOP GASKETS SHALL BE INSTALLED TO JOIN THE SEWER TO THE MANHOLE WALL WHEN A.B.S. COMPOSITE PIPE OR P.V.C. PIPE IS USED. FOR OTHER TYPES OF PIPE THE SEWER SHALL BE GROUTED IN PLACE WITH NON-SHRINK GROUT. THE SEWER PIPE SHALL BE SUPPORTED WITH CONCRETE ENCASUREMENT A MINIMUM OF 3 FEET FROM THE MANHOLE WALL AND TO THE FIRST JOINT FOR V.C.P. SUCH THAT THE JOINT REMAINS FLEXIBLE.
4. ALL INSIDE SURFACES OF THE CONCRETE MANHOLE WHICH WOULD BE EXPOSED TO SEWER GAS SHALL BE COATED WITH 2 COATS THEWEC SERIES 88 HI-BUILD EPOXYLINE, DRY THICKNESS OF 8 MILS (MIN.)
5. EXTERIOR MANHOLE WALLS SHALL BE COATED WITH 1 COAT MOBILARMA 633 BITUMINOUS COATING.
6. JOINT SEALING COMPOUND SHALL BE KENT SEAL NO. 2 OR APPROVED EQUAL.
7. PRECAST MANHOLES SHALL BE SET AT LEAST 4 INCHES INTO THE MANHOLE BASE.
8. TOP OF MANHOLE FLOOR SLAB SHALL BE AT LEAST 3 INCHES BELOW THE FLOW LINE OF THE OUTLET PIPE TO INSURE SUFFICIENT MINIMUM THICKNESS OF SHAPED INVERT.
9. LIFTING HOLES SHALL BE FILLED WITH NON-SHRINK GROUT AND THE INTERIOR SURFACE COATED AS SPECIFIED.
10. MORTAR USED IN MASONRY CONSTRUCTION SHALL CONTAIN 8 SACKS OF CEMENT PER CUBIC YARD. CONCRETE USED IN MANHOLE BASES SHALL CONFORM TO THE REQUIREMENTS OF CONCRETE FOR CONCRETE PAVEMENT CONSTRUCTION AS SPECIFIED IN THE CITY STANDARD PAVING SPECIFICATIONS USING CITY CONCRETE PAVEMENT MIX WITHOUT AIR ENTRAINING ADMIXTURE. MORTAR SHALL BE PLACED AROUND THE MANHOLE RING AS SHOWN ON THE DRAWINGS WHEN MANHOLES ARE CONSTRUCTED IN UNPAVED AREAS. MANHOLES CONSTRUCTED WHERE PIPE SIZES ARE SMALLER THAN 24" SHALL HAVE AN INSIDE DIAMETER OF 4". MANHOLES CONSTRUCTED WHERE PIPE SIZES ARE 24" OR LARGER SHALL HAVE AN INSIDE DIAMETER OF 5". COMPLETED MANHOLE SHALL BE WITHOUT LEAKS AND WATER TIGHT.

11. REINFORCING STEEL SHALL BE INSTALLED IN THE MANHOLE BASES AND SHALL CONSIST OF NO. 4 BARS PLACED ON 6" CENTERS IN BOTH DIRECTIONS. THE MANHOLE BASE REINFORCEMENT SHALL BE PLACED AT LEAST 3" ABOVE THE BOTTOM OF THE MANHOLE BASE. ALL COSTS FOR FURNISHING AND INSTALLING REINFORCING STEEL SHALL BE INCLUDED IN THE UNIT PRICE BID FOR THE MANHOLE.
12. OPENINGS SHALL BE CUT INTO THE MANHOLE WALL WHEN OUTSIDE DROPS ARE CONSTRUCTED ON EXISTING MANHOLES. SUCH OPENINGS CUT INTO EXISTING MANHOLES SHALL BE AS SMALL AS PRACTICAL TO FACILITATE INSTALLING AND GROUTING THE NEW PIPE IN PLACE. WATERSTOP GASKETS SHALL BE USED WITH P.V.C. AND A.B.S. COMPOSITE PIPE. THE NEW PIPE SHALL BE GROUTED INTO THE OPENING USING AN APPROVED NONSHRINK GROUT FOR THE FULL MANHOLE WALL THICKNESS. THE EXTERIOR OF THE COMPLETED CONNECTION SHALL BE SEALED WITH AN APPROVED BITUMINOUS COATING SUCH THAT THE CONNECTION WILL BE WATER TIGHT. FLOOR OF MANHOLE SHALL BE MODIFIED TO FORM NEW FLOW CHANNEL FOR THE NEW CONNECTION AS INDICATED BY THE DRAWING. THIS WORK, INCLUDING MODIFICATION OF MANHOLE FLOOR, SHALL BE PAID FOR AT THE UNIT PRICE BID FOR OUTSIDE DROP STACK CONSTRUCTED ON EXISTING MANHOLE.
13. THE FLOORS OF ALL MANHOLES SHALL BE SHAPED WITH FLOW CHANNELS SUCH THAT THE MANHOLES WILL BE SELF-CLEANING AND FREE OF AREAS WHERE SOLIDS COULD BE DEPOSITED AS SEWAGE FLOWS THROUGH THE MANHOLE FROM ALL INLET PIPES TO THE OUTLET PIPE. FLOW CHANNELS SHALL BE FORMED TO MATCH THE BOTTOM HALVES OF THE INFLOWING PIPES AND THE OUTFLOWING PIPE AS SHOWN BY THE DRAWINGS EXCEPT FOR INSIDE DROP MANHOLES. FLOW CHANNELS FOR INSIDE DROP MANHOLES SHALL BE CONSTRUCTED AS INDICATED BY THE DRAWING. MANHOLE FLOORS SHALL HAVE SLOPES OF 3 INCHES PER FOOT IN THE AREAS OUTSIDE OF THE FLOW CHANNELS SLOPED TOWARD THE FLOW CHANNELS. PIPES LAID THROUGH MANHOLES SHALL HAVE THE TOP HALF REMOVED TO NEAT LINES FOR THE FULL INSIDE DIAMETER OF THE MANHOLE. MANHOLE FLOORS SHALL THEN BE SHAPED AROUND THE BOTTOM HALF OF THE PIPE WHICH FORMS THE FLOW CHANNEL.
14. PIPES INSTALLED WITHIN THE EXCAVATION MADE FOR THE MANHOLE SHALL BE CRADLED WITH CONCRETE TO THE LIMITS OF THE MANHOLE EXCAVATION. WHEN CLAY PIPE IS USED, THE CRADLE SHALL EXTEND TO THE FIRST JOINT OUTSIDE THE MANHOLE. THE CRADLE SHALL BE TERMINATED AT THE CLAY PIPE JOINT IN A MANNER WHICH WILL MAINTAIN THE FLEXIBILITY OF THE JOINT. COST OF CRADLE WITHIN MANHOLE EXCAVATION OR TO CLAY PIPE JOINTS ADJACENT TO MANHOLE SHALL BE INCLUDED IN THE UNIT PRICE BID FOR THE MANHOLE.

15. MANHOLE COVER CASTINGS AND MANHOLE FRAME CASTINGS SHALL CONFORM TO THE REQUIREMENTS AS INDICATED IN THE STANDARD SPECIFICATIONS AND AS SHOWN IN THE STANDARD DETAIL DRAWING.
16. THE VERTICAL DROP IN INSIDE DROP MANHOLES SHALL NOT EXCEED 4' FOR INFLOWING PIPES SIZED 12" OR SMALLER AND 2' FOR INFLOWING PIPES LARGER THAN 12". THE CROWNS OF INFLOWING PIPES SHALL NEVER BE SET LOWER THAN THE CROWN OF THE OUTFLOWING PIPE.
17. STANDARD MANHOLES AND STANDARD INSIDE DROP MANHOLES SHALL BE BID AS STANDARD MANHOLES FOR THE TYPE AND DIAMETER INDICATED. OUTSIDE DROP MANHOLES SHALL BE BID AS STANDARD OUTSIDE DROP MANHOLES FOR THE TYPE AND DIAMETER INDICATED. ALL MANHOLE DIAMETERS WILL BE 4' UNLESS INDICATED OTHERWISE.
18. A BRICK MASONRY COLLAR SHALL BE INSTALLED BETWEEN THE CAST IRON FRAME AND THE CONCENTRIC CONE. THE COLLAR WILL HAVE 8" WALLS AND A VERTICAL HEIGHT OF 6" MINIMUM AND 18" MAXIMUM. A 1" COAT OF MORTAR WILL BE PLASTERED ON THE OUTSIDE OF THE COLLAR.

City of Wichita, Kansas

Technical drawing of a manhole structure, showing dimensions and construction details. The drawing includes the following labels and dimensions:

- SEE GEN. NOTES** (top right)
- 8" MIN. - 18" MAX. BRICK MASONRY COLLAR** (left side, vertical dimension)
- 26" MIN.** (top width dimension)
- 8" BRICK MASONRY** (top right, horizontal dimension)
- 1" COAT OF MORTAR** (top right, horizontal dimension)
- MANHOLE WALL CITY CONC. PAV'T MIX** (right side, vertical dimension)
- 30" MIN.** (middle width dimension)
- 30" MIN. - 48" MAX.** (left side, vertical dimension)
- 8"** (middle width dimension, below 30" MIN.)
- NOTE: CROWN OF PIPE FLOWING IN SHALL NOT BE LOWER THAN CROWN OF PIPE FLOWING OUT** (right side, diagonal dimension)
- FLOOR SHAPING SLOPE - 3" TO 1"** (bottom right, diagonal dimension)
- 9" MIN.** (bottom left, vertical dimension)
- MANHOLE BASE CITY CONC. PAV'T MIX** (bottom right, horizontal dimension)
- SEE GEN. NOTES** (bottom center, horizontal dimension)
- 4" MIN.** (bottom left, horizontal dimension)
- 4" MIN.** (bottom center, horizontal dimension)
- 8"** (bottom right, horizontal dimension)

SEE GEN NOTES

8" BRICK MASONRY

1" COAT OF MORTAR

MANHOLE WALL

CITY CONC PAV'T MIX

6 SACK SAND MIX FOR PIPE SUPPORT TO LIMIT OF EXCAV

9' MIN.

MANHOLE BASE

RING AND LID AS SPECIFIED

26"

1"

30"

8" MIN 18" MAX

MASONRY COLLAR

30' MIN - 45' MAX

NOTE BOTTOM SHALL BE CUTTING OUTFLOWING

FLOOR SHAPIN

VARIABLE

SEE GEN NOTES

4" MIN.

8"

4" MIN.

1. HORTAR USED IN MASONRY CONSTRUCTION SHALL CONTAIN 8 BAGS OF CEMENT PER CUBIC YARD. CONCRETE USED IN MANHOLE WALLS AND BASES SHALL CONFORM TO THE REQUIREMENTS OF CONCRETE FOR CONCRETE PAVEMENT CONSTRUCTION AS SPECIFIED IN THE CITY STANDARD PAVING SPECIFICATIONS USING CITY CONCRETE PAVEMENT MIX WITHOUT AIR ENTRAINING ADMITTURE. HORTAR SHALL BE PLACED IN THE JOINTS BETWEEN THE MANHOLE WALLS. DRAININGS WHEN MANHOLES ARE CONSTRUCTED IN UNPAVED AREAS, TYPE "C" MANHOLES CAN BE CONSTRUCTED ONLY WHERE PIPE SIZES ARE 8" OR SMALLER. THE INSIDE DIAMETER OF TYPE "C" MANHOLES SHALL BE 4". COMPLETED MANHOLE SHALL BE WITHOUT LEAKS AND WATER TIGHT.
2. REINFORCING STEEL SHALL BE INSTALLED IN THE MANHOLE BASE. REINFORCING STEEL SHALL CONSIST OF NO. 4 BARS PLACED ON 6" CENTERS IN BOTH DIRECTIONS. REINFORCING STEEL SHALL BE PLACED 6" ABOVE THE BOTTOM OF THE MANHOLE. THE COST OF PURCHASING AND INSTALLING THE REINFORCING STEEL SHALL BE INCLUDED IN THE UNIT PRICE BID FOR THE MANHOLE.
3. AN OPENING SHALL BE CUT IN THE MANHOLE WALL FOR THE UPPER INLET PIPE FOR INSIDE AND OUTSIDE DROP MANHOLES. THE UPPER INLET PIPE SHALL BE PLACED INTO THE MANHOLE WITH NON-SHAKING GROUT. THE EXTERIOR OF THIS COMPLETED CONNECTION SHALL BE SEALED WITH AN APPROVED BITUMINOUS COATING SUCH THAT THE CONNECTION WILL BE WATER TIGHT.
4. THE FLOORS OF ALL MANHOLES SHALL BE SHAPED WITH FLOW CHANNELS SUCH THAT THE MANHOLES WILL BE SELF CLEANSING AND FREE OF AREAS WHERE SOLIDS COULD BE DEPOSITED AS SEWAGE FLOWS THROUGH THE MANHOLE FROM ALL INLET PIPES TO THE OUTLET PIPE. FLOW CHANNELS SHALL BE FORMED TO FOLLOW THE ARCH OF THE MANHOLE. THE FLOW CHANNELS SHALL BE OUTSLUING PIPES AS SHOWN BY THE DRAWINGS EXCEPT FOR INSIDE DROP MANHOLES. FLOW CHANNELS FOR INSIDE DROP MANHOLES SHALL BE CONSTRUCTED AS INDICATED BY

THE DRAWING. MANHOLE FLOORS SHALL HAVE SLOPES OF 3 INCHES PER FOOT IN THE AREAS OUTSIDE OF THE FLOW CHANNELS SLOPED TOWARD THE FLOW CHANNELS. PIPES LAID THROUGH MANHOLE SHALL HAVE THE TOP HALF REMOVED TO NEAT LINES FOR THE FULL INSIDE DIAMETER OF THE MANHOLE. MANHOLE FLOORS SHALL THEN BE SHAPED AROUND THE BOTTOM HALF OF THE PIPE WHICH FORMS THE FLOW CHANNEL.

5. PIPES INSTALLED WITHIN THE EXCAVATION MADE FOR THE MANHOLE SHALL BE GRADED WITH CONCRETE TO THE LIMITS OF THE MANHOLE EXCAVATION. WHEN CLAY PIPE IS USED, THE CRADLE SHALL EXTEND TO THE FIRST JOINT OUTSIDE THE MANHOLE. THE CRADLE SHALL BE TERMINATED AT THE CLAY PIPE JOINT IN A MANNER WHICH WILL MAINTAIN THE FLEXIBILITY OF THE JOINT. COST OF CRADLE WITHIN MANHOLE EXCAVATION OR TO CLAY PIPE JOINTS ADJACENT TO MANHOLE SHALL BE INCLUDED IN THE UNIT PRICE BID FOR THE MANHOLE.
6. MANHOLE COVER CASTINGS AND MANHOLE FRAME CASTINGS SHALL CONFORM TO THE REQUIREMENTS AS INDICATED IN THE STANDARD SPECIFICATIONS AND AS SHOWN IN THE STANDARD DETAIL DRAWING.
7. THE VERTICAL DROP IN INSIDE DROP MANHOLES SHALL NOT EXCEED 4" FOR INFLOWING PIPES SIZED 12" OR SMALLER AND 2" FOR INFLOWING PIPES LARGER THAN 12". THE CROWNS OF INFLOWING PIPES SHALL NEVER BE SET LOWER THAN THE CROWN OF THE OUTFLOWING PIPE.
8. STANDARD MANHOLES TYPE "C" AND STANDARD INSIDE DROP MANHOLES TYPE "C" SHALL BE BID AS STANDARD MANHOLES FOR THE TYPE AND DIAMETER INDICATED. OUTSIDE DROP MANHOLES TYPE "C" SHALL BE BID AS STANDARD OUTSIDE DROP MANHOLES FOR THE TYPE AND DIAMETER INDICATED. ALL MANHOLE DIAMETERS WILL BE 4' UNLESS INDICATED OTHERWISE.


SEWER APPURTENANCES DETAILS

ADOPTED AS STANDARD DESIGN


BY

CITY OF WICHITA, KANSAS


TYPE "D" MANHOLE



TYPE "D" INSIDE DROP MANHOLE



TYPE "D" OUTSIDE DROP MANHOLE



GENERAL NOTES

1. MORTAR USED IN MASONRY CONSTRUCTION SHALL CONTAIN 8 SACKS OF CEMENT PER CUBIC YARD. CONCRETE USED IN MANHOLE WALLS AND BASES SHALL CONFORM TO THE REQUIREMENTS OF CONCRETE FOR CONCRETE PAVEMENT CONSTRUCTION AS SPECIFIED IN THE CITY STANDARD PAVING SPECIFICATIONS USING CITY CONCRETE PAVEMENT MIX WITHOUT AIR ENTRAINING AD MIXTURE. MORTAR SHALL BE PLACED AROUND THE MANHOLE RING AS SHOWN ON THE DRAWINGS WHEN MANHOLES ARE CONSTRUCTED IN UNPAVED AREAS.
2. ALL INSIDE SURFACES OF THE CONCRETE MANHOLE WALL WHICH WOULD BE EXPOSED TO SEWER GAS SHALL BE PROTECTED BY AN APPROVED EPOXY COATING. TYPE "D" MANHOLES MAY BE USED ON PIPE SIZES 8" TO 24" WHEN THE MANHOLE WALL IS 8" THICK. THE REQUIRED CORREL HEIGHT BY 1" PLUS THE OUTSIDE DIAMETER OF THE PIPE IN THE MANHOLE.
3. MANHOLES CONSTRUCTED WHERE PIPE SIZES ARE SMALLER THAN 8" SHALL HAVE A DIAMETER OF 4". MANHOLES CONSTRUCTED WHERE THE LARGER SHALL HAVE A DIAMETER OF 5". THE HEIGHT OF MANHOLES SHALL BE 4' MANHOLES HAVING A DIAMETER OF 6" IN HEIGHT. COMPLETED MANHOLE SHALL BE TIGHT.
4. REINFORCING STEEL SHALL BE INSTALLED IN THE MANHOLE WALL. REINFORCING STEEL SHALL BE PLACED 6" ABOVE THE MANHOLE BASE. COST OF FURNISHING AND INSTALLING REINFORCING STEEL SHALL BE INCLUDED IN THE UNIT PRICE BID FOR THE MANHOLE.
5. AN OPENING SHALL BE CUT IN THE MANHOLE WALL FOR THE UPPER INLET PIPE FOR INSIDE AND OUTSIDE DROP MANHOLES. THE UPPER INLET PIPE SHALL BE GROUTED INTO THIS OPENING WITH NON-SHRINK GROUT. THE EXTERIOR OF THIS COMPLETED CONNECTION SHALL BE SEALED WITH AN APPROVED BITUMINOUS COATING SUCH THAT THE CONNECTION WILL BE WATER TIGHT. THE INTERIOR PLASTIC LINING SHALL BE SEALED AROUND THE INLET PIPE OPENING IN SUCH A MANNER THAT WILL EFFECTIVELY MAINTAIN THE INTEGRITY OF THE PROTECTIVE PLASTIC LINER.
6. THE FLOORS OF ALL MANHOLES SHALL BE SHAPED WITH FLOW CHANNELS SUCH THAT THE MANHOLES WILL BE SELF-CLEANING AND FREE OF AREAS WHERE SOLIDS COULD BE DEPOSITED AS SEWAGE FLOWS THROUGH THE MANHOLE FROM ALL INLET PIPES TO THE

OUTLET PIPE. FLOW CHANNELS SHALL BE FORMED TO MATCH THE BOTTOM HALVES OF THE INFLUING PIPES AND THE OUTFLOWING PIPE AS SHOWN BY THE DRAWINGS EXCEPT FOR INSIDE DROP MANHOLES. FLOW CHANNELS FOR INSIDE DROP MANHOLES SHALL BE CONSTRUCTED AS INDICATED BY THE DRAWINGS. MANHOLE FLOORS SHALL HAVE SLOPES OF 3 INCHES PER FOOT IN THE AREAS OUTSIDE OF THE FLOW CHANNELS SLOPES TOWARD THE FLOW CHANNELS. FLOORS FOR THE FULL INSIDE DIAMETER OF THE MANHOLE SHALL BE SHAPED TO MATCH THE BOTTOM HALF OF THE PIPE WHICH FORMS THE FLOW CHANNEL.

PIPES INSTALLED WITHIN THE EXCAVATION MADE FOR THE MANHOLE SHALL BE USED WITH CONCRETE TO THE LIMIT OF THE MANHOLE EXCAVATION. WHEN PIPE IS USED, THE CHANNEL SHALL EXTEND TO THE FIRST JOINT IN THE MANHOLE. THE CHANNEL SHALL BE TERMINATED AT THE JOINT IN A MANNER WHICH WILL MAINTAIN THE FLEXIBILITY OF THE JOINT. JOINTS WITHIN MANHOLE EXCAVATION UP TO CLAY PIPE ADJACENT TO MANHOLE SHALL BE INCLUDED IN THE UNIT PRICE BID FOR THE MANHOLE.

MANHOLE COVER CASTINGS AND MANHOLE FRAME CASTINGS SHALL CONFORM TO THE REQUIREMENTS AS INDICATED IN THE STANDARD SPECIFICATIONS AND AS SHOWN IN THE STANDARD DETAIL DRAWING.

7. THE VERTICAL DROP IN INSIDE DROP MANHOLES SHALL NOT EXCEED 4' FOR INFLUING PIPES SIZED 12" OR SMALLER AND 2' FOR INFLUING PIPES LARGER THAN 12". THE CROWNS OF INFLUING PIPES SHALL NEVER BE SET LOWER THAN THE CROWN OF THE OUTFLOWING PIPE.

8. STANDARD MANHOLES TYPE "D" AND STANDARD INSIDE DROP MANHOLES TYPE "D" SHALL BE BID AS STANDARD MANHOLES FOR THE TYPE AND DIAMETER INDICATED. OUTSIDE DROP MANHOLES TYPE "D" SHALL BE BID AS STANDARD OUTSIDE DROP MANHOLES FOR THE TYPE AND DIAMETER INDICATED. ALL MANHOLE DIAMETERS WILL BE 4' UNLESS INDICATED OTHERWISE.


NOTE: EPOXY COATING ON INTERIOR CONCRETE SURFACES MAY BE OMITTED WHEN TYPE "D" MANHOLES ARE CONSTRUCTED IN SEWERS WITH DIAMETERS SMALLER THAN 12".

MANHOLE FRAME AND COVER DETAIL


ADOPTED AS STANDARD DESIGN
BY

City of Wichita, Kansas

MANHOLE COVER
Weight: 180 Lbs.




TOP VIEW




BOTTOM VIEW

PICKHOLE DETAIL




SECTION VIEW




SECTION VIEW

* OUTSIDE DIA. TOP OF COVER
** OUTSIDE DIA. BOTTOM OF COVER

MANHOLE FRAME
Weight: 240 Lbs.



TOP VIEW



SECTION A-A


GENERAL NOTES

1. MANHOLE CASTINGS SHALL BE MANUFACTURED USING GOOD QUALITY GRAY IRON CONFORMING TO CLASS 30 OF A.S.T.M. DESIGNATION A-48. DIMENSIONS AND WEIGHTS SHOWN ON THE DETAIL DRAWINGS SHALL BE CONSIDERED AS MINIMUM REQUIREMENTS AND ANY DEVIATIONS FROM THE DIMENSIONS SHOWN MUST BE SPECIFICALLY APPROVED. THE FINISHED CASTINGS SHALL BE OF UNIFORM QUALITY, FREE FROM BLOWHOLES, POROSITY, HARD SPOTS, SHRINKAGE DISTORTIONS OR OTHER DEFECTS.
2. MANHOLE CASTINGS SHALL BE COATED WITH AN ASPHALT PAINT RESULTING IN A SMOOTH, TOUGH AND TENACIOUS COATING WHICH IS NOT BRITTLE OR TACKY.
3. MANHOLE CASTINGS SHALL BE MANUFACTURED SUCH THAT A COVER MANUFACTURED BY ANY ONE FOUNDRY WILL FIT INTERCHANGEABLY INTO A FRAME MANUFACTURED BY ANOTHER FOUNDRY AND STILL MEET ALLOWABLE CLEARANCES AND NON-ROCKING REQUIREMENTS. THIS WILL REQUIRE MANUFACTURING OF THE MATCHING FACES ON THE COVER AND THE FRAME TO CLOSE TOLERANCES.
4. THE OUTSIDE CIRCUMFERENCE OF THE VERTICAL FACE OF THE COVER AND THE INSIDE CIRCUMFERENCE OF THE VERTICAL FACE IN THE FRAME RECESS SHALL BE MANUFACTURED TO TOLERANCES SUCH THAT THE CLEARANCE BETWEEN THE COVER AND FRAME WILL NOT EXCEED 1/8" AT ANY POINT AROUND THE CIRCUMFERENCE OF THE COVER. THE SEATING SURFACES BETWEEN THE COVER AND FRAME SHALL BE MACHINED SUCH THAT THESE SURFACES SHALL MAKE FULL CONTACT FOR THEIR FULL CIRCUMFERENCE TO PRECLUDE THE COVER FROM ROCKING IN THE FRAME.
5. THE MANHOLE FRAME AND COVER SHALL BE MARKED WITH LETTERING INDICATING THE NAME OF THE MANUFACTURER AND THE YEAR WHEN THE COVER OR FRAME WAS CAST. THE COVER SHALL BE FURTHER IDENTIFIED WITH REGARDS TO OWNERSHIP USING LETTERS AT LEAST 1" IN HEIGHT. THIS IDENTIFICATION SHALL BE "CITY OF WICHITA SEWER DEPARTMENT". THE WORD DEPARTMENT MAY BE ABBREVIATED. THE TEXTURE OF THE TOP SURFACE OF THE COVER SHALL BE MANUFACTURED IN A CHECKERED PATTERN DESIGN AS INDICATED ON THE DRAWINGS. SMOOTH BLOCKOUTS SHALL BE UTILIZED TO HIGHLIGHT THE LETTERING ON THE COVER SURFACE. THE TOTAL AREA OF SMOOTH SURFACE BLOCKOUT SHALL NOT EXCEED THE AREA AS INDICATED ON THE DRAWING. POSITIONING OF SMOOTH BLOCKOUTS AND LETTERING MAY VARY FROM THAT SHOWN ON THE DETAILED DRAWING.


VERTICAL RISER DETAIL

ADOPTED AS STANDARD DESIGN
BY

CITY OF WICHITA, KANSAS



TYPICAL RISER FOR SLOPING TRENCH WALLS



TYPICAL RISER FOR VERTICAL TRENCH WALLS

GENERAL NOTE

[illegible]

FURNISHING AND INSTALLING RISERS SHALL BE PAID FOR AT THE UNIT PRICES BID FOR "PIPE, 2" PIPE AND REINFORCED CONCRETE ENCASEMENT FOR THE VARIOUS MAIN SEWER PIPE SIZES INDICATED: WHICH PRICE SHALL INCLUDE ALL COSTS FOR COMPLETION OF THIS ITEM INCLUDING SADDLES, BENDS, CONCRETE, REINFORCING STEEL, CAPS OR PLUGS, AND ALL OTHER NECESSARY MATERIALS OR WORK. CONCRETE ENCASEMENT OF THE RISER PIPE TO THE TOP OF THE BEND AS SHOWN BY THE DRAWINGS WILL NOT BE PAID FOR DIRECTLY AND THE COST FOR THIS WORK SHALL BE CONSIDERED AS SUBSIDIARY TO THE OTHER ITEMS OF WORK.

THE PROJECT INSPECTOR SHALL REPORT ON INSPECTOR CARDS THE LOCATION OF ALL RISERS CONSTRUCTED AS MEASURED FROM THE NEAREST MANHOLE, THE DIRECTION OF SERVICE, THE ELEVATION OF THE TOP OF THE RISER, AND THE PAY QUANTITIES INVOLVED. THE PROJECT INSPECTOR SHALL ALSO REPORT ON INSPECTOR CARDS THE LOCATION, DIRECTION OF SERVICE, AND SIZE OF ALL STUBS INSTALLED IN MANHOLES.

NOTE:
TOP OF 4" OR 6" RISER PIPE TO BE
EXTENDED TO AN ELEVATION OF 1 ft
MINIMUM ABOVE THE WATER TABLE
ELEVATION, WHEN WATER EXISTS,
OR TO AN ELEVATION SUITABLE FOR
PROVIDING SERVICE TO THE LOT TO
BE SERVED AND THEN PLUGGED.