#B602.2.a

TAFT AVENUE

FLORENCE ST.

Existing information from City Records - See K-172

Lot 1, "McMillen 2nd Addition"

Lot 1, "Rand Addition"

Sta 0+57 Construct City of Wichita Standard Type "A" Manhole over Existing 8"VCP Plug and abandon Line East.

Sta 1+51 Abandon existing MH. Plug & abandon Line West.

SCALE: 1" = 40' Horiz
1" = 5' Vert

8"

Sta 0+00 Existing Top MH= 116.75

5" @ 1.57% to 1+51.5 Plug and abandon existing 8"VCP per City of Wichita specifications

Existing MH=110.75 Inv. N=105.25 Inv. S=105.00

Existing ±100' 8"VCP

Inv. N=104.75 Inv. S=104.50

120

115

110

105

0 +57 1 +51

NOTE TO CONTRACTOR

This project will be constructed under the supervision of the CITY ENGINEER and conforming to the SPECIFICATIONS of the CITY OF WICHITA. The CONTRACTOR will pay the City of Wichita all [illegible] sewer inspection [illegible]

APPROVED AS NOTED
By CITY ENGINEER OF WICHITA
Sanitary Sewers [illegible]
Storm Sewers
Driveway Approaches

BRUCE WINTER SAMUELS LICENSED #2116 PROFESSIONAL ENGINEER

PRIVATE SANITARY SEWER EXTENSION TO SERVE LOT 1, "MC MILLEN 2ND ADD" AND LOT 1, "RAND ADDITION" AT TAFT AND FLORENCE

PROJ. NO. 468-76-245-80001-000-000-056

Design BB
Drawn TL
Checked BB
Date 3-11-86
Job no.

Sheet 1 of 1

Van Doren Hazard Stallings
Architects · Engineers · Planners
Topeka · Wichita · Minneapolis · Kansas City

1/1