



RFI NO. 10 R.1

**REQUEST FOR INFORMATION  
FROM WILDCAT CONSTRUCTION CO., INC.**

City of Wichita  
Re-Use Water PS (to serve Spirit AeroSystems)

**DATE SUBMITTED:**

7-6-2016

**RESPONSE REQUESTED BY:**

7-6-2016

**SUBMITTED BY:**

Tyler Dehn

**FROM:**

Wildcat (GC)

**SUBJECT:** ALOK Connection Option - URGENT

We are submitting the following product data for an alternate connection option for both the Aeration basin and wet well on the 24" C905 PVC. This would be used in lieu of the plan call out for City of Wichita standard grouted connection. We feel that this will provide a better watertight connection for both sides, which will in most cases always be under water and have head pressure. ~~Finalized pricing should be completed soon and will submit as follow up.~~

We request 0 additional days for this work.

There is \$2,100 for this change.

**RESPONSE:**

**RESPONSE BY:**

**RESPONSE DATE:**