



**Submittal - 024 Pump Station**

Sigma Stainless Steel 304 Flange Pack (Submittal on the following page(s), this sheet is the response page)

**Response:**

<b>MKEC ENGINEERING, INC.</b>	
411 North Webb Road - Wichita KS 67206	
<input checked="" type="checkbox"/> Reviewed	<input type="checkbox"/> Reviewed As Noted
<input type="checkbox"/> Revise and Resubmit	<input type="checkbox"/> Rejected
<input type="checkbox"/> Not Required by the Contract Documents	
Reviewed for conformance with the design concept of the project and compliance with the information given in the contract documents. Contractor is responsible for dimensions to be confirmed and correlated at the job site, information that pertains solely to the fabrication process or to techniques of construction, and coordination of work of all other trades. If "Resubmit" or "Rejected" are not checked resubmission is neither desired or required.	
<i>Belg Steel</i>	Date <i>6-28-16</i>



Quality – Service – Commitment – Delivered.

5000 Askins Lane  
Houston, TX 77093

800 999 0109 p  
281 987 0200 f  
htn-sales@sigmaco.com

## SIGMA Stainless Steel 304 Flange Pack

### CERTIFICATE

This is to certify the components of the Sigma SS304 Flange Pack

1. One Full Faced Red Rubber / Synthetic Rubber ASTM 13303 Class 2 Gasket 1/8" thick.
2. Hexagonal Bolts with Heavy Hex nuts 304 Stainless Steel.

Bolts and Nuts are threaded in accordance with ASME/ANSI B1.1.

The flange packs are applicable for use with AWWA C110 Flanged Fittings.

Please contact me if you need any further documentation on this matter.

Regards,

Jim Stohr  
Branch Manager  
Sigma Corporation  
Houston, Texas