



**TRAP AREA**

NOTE: 6" wyes used on this project.

**LAT. 2, SUB. 1, S.S. NO. 22**

UTILITY CONT. INC.      JUNE 29, 1954

BK. NO. JI. 64      PROJ. NO. C24-5

CONSTRUCTION RECORD

SERVICE RECORD

STATION	ELEVATION		Depth	MANHOLE	4-INCH "Y" BRANCHES		No. of Permit		House Number		DATE OF PERMITS			
	Ground	Grade			North West	South East	North West	South East	North West	South East	North West	South East	North West	South East
Line # 1	0+0	89.6	82.50	7.1	0+00 Exist'g MH.	0+73.5	0+76.5	1405	1400	1239	1238 R	See Below	7-10-53	
1+0	90.0	82.60	7.4		1+55.8	1+58.8	1406	1401	1233 R	1232 R	10-4-54	7-10-53		
2+0	90.2	82.70	7.5		2+15.6	2+18.6	1407	1402	1227	1226	7-6-54	7-6-54		
3+0	90.5	82.80	7.7	2+98.5	2+73.5	2+78.5	1408	1403	1227	1226	7-6-54	7-6-54		
4+0	91.3	82.90	8.4		3+43.6	3+46.6	1409	1404	1214	1214	4-29-55	7-6-54		
5+0	91.3	83.00	8.3		4+61.6	4+64.6	44548	4480	1201	1201	4-29-55	5-1-57		
6+0	92.0	83.10	8.9	5+98.2	5+28.0	5+31.0	44547	4481	1137 R	1137	4-29-55	5-1-57		
7+0	91.8	83.20	8.6		6+57.8	6+60.8	44545	4483	1125	1124	4-29-55	5-1-57		
8+0	92.0	83.30	8.7		7+24.0	7+27.8	44809	4481	1119	1120	8-23-54	8-23-54		
	93.0	83.39	9.6	8+88.8	8+40.0	8+63.0	44807	4482	1109	1108	8-23-54	8-23-54		
Line # 2	0+0	89.6	82.50	7.1	0+00 Exist'g MH.	0+32.6	0+35.6	1339	1329	1425	1426	6-28-54	6-28-54	
1+0	89.4	82.60	6.8		1+07.7	1+10.7	1331	1321	1419	1420	6-28-54	6-28-54		
2+0	89.1	82.70	6.4		1+72.0	1+75.0	1332	1322	1415	1414	6-28-54	6-28-54		
3+0	89.4	82.80	6.6		2+39.0	2+42.0	1333	1323	1409	1408	6-28-54	6-28-54		
4+0	89.9	82.90	7.0		3+13.0	3+16.0	1334	1324	1407	1406	6-28-54	6-28-54		
5+0	89.7	83.00	6.7		3+65.7	3+68.7	1335	1325	1374	1326	6-28-54	6-28-54		
6+0	89.5	83.10	6.4		4+33.5	4+36.5	1336	1326	1319	1320	6-28-54	6-28-54		
	89.8	83.15	6.7	6+49.1	5+00.9	5+03.9	1337	1327	1315	1314	6-28-54	6-28-54		
					5+61.4	5+64.4	1338	1328	1308	1308	6-28-54	6-28-54		
					6+27.8	6+30.8	1339	1329	1301	1302	6-28-54	6-28-54		

2001-00440- 2/28/02-1326 E 31<sup>st</sup> Sts- McClungs- 4" sch 40 Donut 21' w of MH 3+24.5 (3+03.5) trap installed, 17WINCO, 1022, Fernis to CI@house

2002-00755- 3/19/02- 1420 E 31<sup>st</sup> Sts- Wichita Exc- twin co, new trap, 4" sch 40 14" G.U. 1H22, 1V22, 1V45, tied to wye w/ donut.

2003-01811- 7/10/03- 1232 E 31<sup>st</sup> Sts- Reddi Rootr - 4" PVC- 1TWINCO, 1V22, 1H22, new house trap, tied to 6" claytile

2003-01818- 7/10/03- 1238 E 31<sup>st</sup> Sts- Reddi Rootr- 4" PVC, 1TWINCO, 1H45, New house trap, 3V22, tied to claytile

2003-03389- 12/30/03- 1137 E Gridley- McClung- 4" PVC, 1TWINCO, 1H23, 2V22, new house trap, shallow, city inspected wye (good) full replacement 70' E of MH 5+98.2 (5+28.2)

A 1409- 1215 Gridley - 7-6-54 - Smith Plmby and Utg. - 6" on 8' wye