



CONSTRUCTION RECORD

SERVICE RECORD

LAT  
LINE 1  
CONT'D

STATION	ELEVATION		Depth	MANHOLE	4-INCH "Y" BRANCHES		No. of Permit		House Number		DATE OF PERMITS		
	Ground	Grade			North West	South East	North West	South East	North West	South East	North West	South East	
14+00	165.4 165.3	156.64 156.74	8.8 8.6	14+33.3		14+18.7		2675		8620-22 Thurman		2-24-81	
15+00	165.0	156.94	8.1		4" sch 40 15+23.3	3" PVC 15+41.8	955001	2001-00078 2676	1629 Robinson	842-14 R Thurman	see next pg 1-11-81	2-24-81	
16+00	164.9	157.24	7.7		4" SDR 35 15+57.0	16+26.8	95-10857	2677	1625 Robinson	8606-8 Thurman	7-14-85	2-24-81	
17+00	164.8 164.8	157.54 157.64	7.3 7.2	17+36.4	4" SDR 35 17+40	17+30.0	94-4887	2678	1621 Robinson	8528-30 Thurman	3-29-94	2-24-81	
18+00	165.2	157.84	7.4		4" SDR 35 18+07.6	17+72.4	94-4227	2679	1617 N Robinson	8520-82 Thurman	6-16-94	2-24-81	
19+00	166.0	158.14	7.9		4" SDR 35 18+39.4 top	18+32.0	93-2554-1		1013 N Robinson	8512-14 Thurman	8-16-93	2-24-81	
20+00	167.1 167.0	158.44 158.55	8.7 8.5	20+36.4	4" SDR 35 20+13.4 top	20+55.4	93-2558-7		1609 Robinson	8504-6 Thurman	2-18-94	2-24-81	
21+00	166.6	158.74	7.9		4" SDR 35 21+30.0	21+31.4	93-25067-7	2682	1601 N Robinson	8446-48 Thurman	9-22-93	2-24-81	
22+00	165.7	159.04	6.7		4" SDR 35 22+26.6 top	22+29.6	94-4294-7	2683	1413 W Robinson	8432-34 Thurman	9-2-94	2-24-81	
23+00	165.3 165.3	159.34 159.52	6.0 5.8	23+60.6	4" SDR 35 23+54.6	23+08.6	95-17059-7	2684	8409 Aberdeen	8422-24 Thurman	3-14-96	2-24-81	
						2-6" STUBS SE	95-17059-7	2685	8405 Aberdeen	8412-14 Thurman	10-26-95	2-24-81	
							95-17059-7	2686	8401 Aberdeen	8404-6 Thurman	8-30-95	2-24-81	
LINE 2 0+00	165.7	154.63	11.1	0+08=7+31 LINE 1	0+45.6 top			7009	8723 Thurman		11-17-82		
1+00	165.5 165.5	154.93 155.19	10.6 10.3	1+86.6	0+97.0 top			3870	8712-14 Thurman	11-15-82		8-11-81	
2+00	165.4	155.23	10.2		1+53.6 top	1+76.6 top		4039	8713-14 Thurman		9-1-81		
3+00	165.0 164.2	155.53 155.82	9.5 8.4	3+97.5	2+77.0 top	2+69.6 top		3871	8707 Thurman	8708 W Thurman	8-11-81	8-11-81	
4+00	164.2	155.83	8.4		2+93.6 top	4+32.5 top		3872	8707 Thurman	8620-22 Thurman	10-12-81	8-11-81	
5+00	164.3	156.13	8.2		3+58.5 top			7008	8623 Thurman		11-17-82		
6+00	163.7	156.43	7.3		4+35.5 top	4+48.5 top		10016	8613 Thurman	8612-14 Thurman	1-13-84	8-11-81	
7+00	163.5	156.73	6.8	7+00.9	5+35.5 top	5+24.9 top		10015	8607 Thurman	8606-8 Thurman	1-13-84	1-23-84	
8+00	163.7	157.03	6.7		6+55.9 top	6+15.9 top		3374	8533 Thurman	8530-32 Thurman	5-23-81	1-23-84	
9+00	163.5 163.5	157.33 157.53	6.2 6.0	9+66.4	6+87.5 top			8780	8525 Thurman	8524-6 Thurman	8-12-83	8-12-83	
10+00	163.5	157.63	5.9		7+55.9 top	7+69.5 top		3373	8525 Thurman	8512-14 Thurman	5-28-81		
11+00	163.5	157.93	5.6		8+11.4 top			5285	8513-4 Thurman	8512-14 Thurman	1-15-82	1-15-82	
12+00	163.7 163.7	158.23 158.33	5.5 5.4	12+33.1	9+11.6 top			5284	8503 Thurman		3-4-82		
					9+93.0 top	9+95.5 top		4882	8504-6 Thurman		12-9-81		
					10+89.4 top	10+19.6 top		5286	8433-4 Thurman	8432-34 Thurman	3-4-82	1-6-82	
								5072	8421-4 Thurman	8422-24 Thurman	1-14-82	1-14-82	
								5287				12-9-81	
								4883					
						2-6" STUBS NE							
LINE 3 0+00	166.6	152.77	13.8	0+00=1+41.3 LINE 1									
1+00	167.4	153.17	14.2										
2+00	168.2	153.57	14.6										
3+00	168.0 168.0	153.97 154.07	14.0 13.9	3+25.5									
						8" STUB E 4" STUB SE		9733		8718 W Thurman		11-29-83	

8413 W Aberdeen Cr - (House line 5" lower than main flowline  
+ RANSET 10-7-94 D. Salina)

SWR 2001-00078 - 11/01 - 8612-14 w Thurman-Woodard Plog - 3" PVC & 1-4x3 Y, 1H45, 2-4" Fernco, 1-3" Fernco