



Do NOT issue
any Bldg Conn
to this main
4/1/98
BL

SCALE 1" = 300'

no Bldg Conn.
must have
ext

MAIN 12 SOUTHWEST INTERCEPTOR SEWER
BUILT BY: CLEARWATER EXCAVATION CO.
PROJ. NO 468-76-245-80914-000-001
BOOKED 1-5-82 FROM DLK 448
PHASE II

on map

plat 4

1-9-91 per City ENG's Office
(Cricky Huang)
NO sewer connections
to Main 12. Must Have Lateral
Extension. Refer to City ENG's
Office on Extensions.
(BL)

4/1/98 - Per Calvin Fugitt
Sewer Maint.
It is opinion of Paul Taylor,
Super Sewer Maint. that
There should be no more
building sewer connections
to this main. It is an
"Outfall" main and not
intended for Bldg conn.
BL

2/27/02 - Per Joe Botinelly
Super - Sewer Maint
Sewer Maintenance recommends
Main extension across
front of lots between
MH's 19+90.8 and 1st 33.6. This is in
Best interest of customer
because of depth of main
(water) and size of lots.
Also "Inlet" fee due unless Main
Ext. done. The Main Ext can end
with C.O. Thus only for one MH.
Capacity is not the issue
as in 1998 because new
NW 7 treat plant will take
some of flow.

Main Ext
Rec'd per
Lorenz plan
system planning
2/27/02

