

I-2

CONSTRUCTION RECORD

SERVICE RECORD

Cont. Main #1

STATION	ELEVATION		Depth	MANHOLE	4-INCH "Y" BRANCHES		No. of Permit		House Number		DATE OF PERMITS	
	Ground	Grade			North West	South East	North West	South East	North West	South East	North West	South East
33+00	151	140.6	10.4									
34+00	151	140.8	10.2									
	150	140.8	9.2	34+36								
35+00	151	141.0	10.0									
36+00	151	141.2	9.8									
	150	141.4	8.6	36+96								
37+00	150	141.4	8.6									
38+00	151	141.6	9.4									
39+00	152	141.8	10.2									
	151	141.9	9.1	39+76								
40+00	151	142.0	9.0									
41+00	151	142.2	8.8									
	151	142.2	8.8	41+26								
42+00	152	142.4	9.6									
43+00	152	142.6	9.4									
44+00	147.5	142.8	4.7									
	150.0	143.0	7.0	44+91								
45+00	150.0	143.1	6.9									
46+00	150.0	143.2	6.8									
47+00	150.0	143.4	8.6									
48+00	150.0	143.6	8.4									
	150.5	143.7	8.8	48+86								
Measurements as found by Sewer Maintenance, Nov. 1982												
	151.09	140.16	10.9	31+11								
	150.41	140.54	9.9	32+80								
	148.81	140.84	8.0	34+25								
	148.19	141.18	7.0	35+99								
	148.73	141.69	7.0	38+18.5								
	152.11	142.99	9.1	44+80.2								
	152.62	143.65	9.0	48+75								

1060- 1150 Bluffview - (Pittsboro School) 8-2-74 - Sealoff - Hoover