

CONSTRUCTION RECORD							SERVICE RECORD					
STATION	ELEVATION		Depth	MANHOLE	4-INCH "Y" BRANCHES		No. of Permit		House Number		DATE OF PERMITS	
	Ground	Grade			North West	South East	North West	South East	North West	South East	North West	South East
SAN SEWER FOR ST FRANCIS SCHOOL												
0+00	154.2	142.07	12.1	0+00								
1+00	153.0	142.39	10.6									
	154.2	142.62	11.6	1+71.1	6" STUB W	6" STUB SW	10020		853			1-13-84
LATERAL 109 MAIN 4 SAN SEWER N ^o 23												
0+00	128.8	119.86	8.9	EXISTING 0+78.4			6583		3146			9-23-82
	129.2	120.38	8.8	0+99.4	4" STUB NW		6577		1033			1-17-83
1+00	128.8	120.39	8.4				6580		1043			9-23-82
	129.2	121.08	8.1	1+73.2	4" STUB NE		6579		1039			9-23-82
LATERAL 68 MAIN 17 SAN SEWER N ^o 22												
0+00	129.5	123.77	5.7	0+00								
1+00	130.5	124.44	6.1									
	130.8	124.52	6.3	1+12.2	4" STUB NE		19238		2035			10/06/87
LATERAL 33 MAIN 3 SW I												
LINE 1 0+00	87.5	82.08	5.4									
	87.5	82.09	5.4	0+17.0								
1+00	87.3	82.60	4.7									
	86.7	82.96	3.7	1+58.4	6" STUB S		7394		4701			1-19-83
LINE 2 0+00	87.5	82.27	5.2	EXISTING 0+00 = 0+17 LINE 1								
	87.4	82.55	4.9	0+68.8	4" Sch 40 PVC 6" STUB SW		222307		1214			5-15-91
LAT 22 MAIN 1 WESTLINK SAN SEWER												
0+00	144.0	134.42	9.6	EXISTING 0+00								
1+35	144.2	134.82	9.4	END PIPE (PLUG) 0+56.6			6701		106 & 8			10-7-82
LAT 43 MAIN 5 SAN SEWER N ^o 23												
0+00	207.6	201.61	6.0	0+00								
1+00	210.7	202.64	8.1				6511		2111 N			9-9-82
2+00	213.1	203.67	9.4									
							13009		6224			1-29-85
3+00	215.5	204.70	10.8									
	218.0	205.74	12.3	4+00.8	6" STUB NW							6-6-84

see I-212