



See L-169

make sure you are not going into storm water MH

Lakeside Mobile Home Park Addn.

30' Utl. Esm't

44+17 MH TP 'D' OUTSIDE DROP

38+17.9 MH TP 'D'

WEST ST.

21\"/>

WEST ST.

1-13-95
Lot 1 Parcel B
MetroWest Inc
G-Rath OK's ave
Bldg Conn to 10\"/>

45+21.4 MH TP 'D'

45+69 to 46+05 CONG. ENCASEMENT

20' Utl. Esm't

34+21.4 35+06 CONG. ENCASEMENT
34+20.6 MH TP 'D'
10\"/>

41+65.4 MH TP 'D'

Lakeside Mobile

15' Utl. Esm't

MO. PAC. R.R.

4300 W
29th S.
Weyerhaeuser
Recyclina
Plant

21\"/>

30+62.6 MH TP 'D'
10\"/>

38+11.9

29th ST. SO.

22+61.4 MH TP 'D'
10\"/>



18+61.9 MH TP 'D'
10\"/>

Unplatted

MO. PAC. R.R.

MAIN 14 SOUTHWEST INTERCEPTOR
468-76-245-81193-000-000-001
BUILT BY WILDCAT CONST.
Booked 5-86 From DLK-463

4-6-7-2

19+61.4 MH TP 'D'
10\"/>

Proposed Bldg
sewer

4300 W
29th S.

Proposed
main sewer
to
this
bldg
7-18-95

10+62.9 MH TP 'D'
10\"/>

9+45 to 10+50 Steel Casing

7+43.2 MH TP 'D'

Section One, Missouri Pacific Industrial Park

4+24.2 MH TP 'D'
30' Utl. Esm't

0+00 EXIST 18\"/>

31st ST. SO.

LINE 1

21\"/>

WEST ST.

18\"/>

MAIN 4, SW I
LINE 1

| CONSTRUCTION RECORD | | | | | | SERVICE RECORD | | | | | | |
|---------------------|-----------|-----------------------|-------|-------------------|---------------------|----------------|---------------|----------------|--------------|------------|-----------------|------------|
| STATION | ELEVATION | | Depth | MANHOLE | 4-INCH "Y" BRANCHES | | No. of Permit | | House Number | | DATE OF PERMITS | |
| | Ground | Grade | | | North West | South East | North West | South East | North West | South East | North West | South East |
| 0+00 | 101.0 | 88.72 | 12.3 | | | | | | | | | |
| | 100.31 | 88.79 OUT 88.86 IN | 11.5 | 0+25 | | | | | | | | |
| 1+00 | 101.0 | 88.95 | 12.1 | | | | | | | | | |
| 2+00 | 101.1 | 89.07 | 12.0 | | | | | | | | | |
| 3+00 | 101.1 | 89.18 | 11.9 | | | | | | | | | |
| 4+00 | 99.0 | 89.30 | 9.7 | | | | | | | | | |
| | 99.52 | 89.33 OUT 89.40 IN | 10.2 | 4+24.2 | | | | | | | | |
| 5+00 | 99.3 | 89.46 | 9.8 | | | | | | | | | |
| 6+00 | 99.0 | 89.53 | 9.5 | | | | | | | | | |
| 7+00 | 98.5 | 89.61 | 8.9 | | | | | | | | | |
| | 99.06 | 89.62 OUT 89.65 IN | 9.4 | 7+43.2 | | | | | | | | |
| 8+00 | 98.9 | 89.71 | 9.2 | | | | | | | | | |
| 9+00 | 98.6 | 89.83 | 8.8 | | | | | | | | | |
| 10+00 | 104.5 | 89.94 | 14.6 | | | | | | | | | |
| | 103.39 | 90.01 OUT 90.09 IN | 13.4 | 10+62.9 | 10" STUB W | | | | | | | |
| 11+00 | 102.9 | 90.12 | 12.8 | | | | | | | | | |
| 12+00 | 102.5 | 90.20 | 12.3 | | | | | | | | | |
| 13+00 | 102.3 | 90.29 | 12.0 | | | | | | | | | |
| 14+00 | 102.2 | 90.37 | 11.8 | | | | | | | | | |
| | 102.25 | 90.42 OUT 90.49 IN | 11.8 | 14+61.4 | 10" STUB W | | | | | | | |
| 15+00 | 101.9 | 90.53 | 11.4 | | | | | | | | | |
| 16+00 | 101.7 | 90.62 | 11.1 | | | | | | | | | |
| 17+00 | 102.2 | 90.71 | 11.5 | | | | | | | | | |
| 18+00 | 102.5 | 90.80 | 11.7 | | | | | | | | | |
| | 102.45 | 90.84 OUT 90.92 IN | 11.6 | 18+61.9 | 10" STUB W | | | | | | | |
| 19+00 | 102.6 | 90.96 | 11.6 | | | | | | | | | |
| 20+00 | 103.8 | 91.08 | 12.7 | | | | | | | | | |
| 21+00 | 104.0 | 91.20 | 12.8 | | | | | | | | | |
| 22+00 | 104.0 | 91.32 | 12.7 | | | | | | | | | |
| | 103.90 | 91.39 | 12.5 | 22+61.4 | 10" STUB W | | | | | | | |
| 23+00 | 103.6 | 91.41 | 12.2 | | | | | | | | | |
| 24+00 | 103.7 | 91.48 | 12.2 | | | | | | | | | |
| 25+00 | 103.7 | 91.54 | 12.2 | | | | | | | | | |
| 26+00 | 104.2 | 91.60 | 12.6 | | | | | | | | | |
| | 104.12 | 91.64 | 12.5 | 26+60.0 | 10" STUB W | 15-7981-7 | | 4350 W 24TH | | 6-2-95 | | |
| 27+00 | 104.2 | 91.67 | 12.5 | | | | | | | | | |
| 28+00 | 104.5 | 91.73 | 12.8 | | | | | | | | | |
| 29+00 | 104.5 | 91.80 | 12.7 | | | | | | | | | |
| 30+00 | 104.7 | 91.87 | 12.8 | | | | | | | | | |
| | 104.67 | 91.91 | 12.8 | 30+62.6 | 10" STUB W | | | | | | | |
| 31+00 | 104.9 | 91.97 | 12.9 | | | | | | | | | |
| 32+00 | 104.5 | 92.12 | 12.4 | | | | | | | | | |
| 33+00 | 104.3 | 92.27 | 12.0 | | | | | | | | | |
| 34+00 | 104.3 | 92.42 | 11.9 | | | | | | | | | |
| | 104.06 | 92.45 | 11.6 | 34+20.6 | 10" STUB NW | | | | | | | |
| 35+00 | 104.0 | 92.56 | 11.4 | | | | | | | | | |
| 36+00 | 103.1 | 92.69 | 10.4 | | | | | | | | | |
| 37+00 | 103.2 | 92.82 | 10.4 | | | | | | | | | |
| 38+00 | 103.3 | 92.95 | 10.4 | | | | | | | | | |
| | 103.67 | 92.97 | 10.7 | 38+11.9 | | | | | | | | |
| 39+00 | 102.5 | 93.04 | 9.5 | | | | | | | | | |
| 40+00 | 103.5 | 93.12 | 10.4 | | | | | | | | | |
| 41+00 | 103.5 | 93.20 | 10.3 | | | | | | | | | |
| | 103.65 | 93.25 | 10.4 | 41+65.4 | | | | | | | | |
| 42+00 | 103.1 | 93.29 | 9.8 | | | | | | | | | |
| 43+00 | 102.9 | 93.41 | 9.5 | | | | | | | | | |
| 44+00 | 103.1 | 93.53 | 9.6 | | | | | | | | | |
| 45+00 | 106.3 | 93.65 | 12.7 | | | | | | | | | |
| | 106.19 | 93.68 | 12.5 | 45+21.4 | | | | | | | | |
| 46+00 | 105.8 | 93.76 | 12.0 | | | | | | | | | |
| 47+00 | 106.7 | 93.87 | 12.8 | | | | | | | | | |
| 48+00 | 105.8 | 93.97 | 11.8 | | | | | | | | | |
| 49+00 | 105.5 | 94.07 | 11.4 | | | | | | | | | |
| | 106.05 | 94.09 OUT 94.73 IN | 12.0 | 49+17.0 | | | | | | | | |
| | | 95.39 | | EXIST. 94+40.0 | | | 1562847 | 2533 WEST | | 5-2-85 | | |