



# Warranty

**VULCAN INDUSTRIES**, warrants all equipment of its own manufacture to be free of defects caused by faulty material or workmanship and shall, of its option, exchange or repair without charge, F.O.B. its factory, such part or parts thereof that prove defective under normal use within twenty-four (24) months from date of actual start-up. **VULCAN INDUSTRIES** obligation under this warranty is limited to the above and does not apply to replacement or repairs which are required as the result of improper installation, misuse, maladjustment, abnormal operating conditions, or lack of routine maintenance. Nor does the warranty include the furnishing of service for maintenance or problems arising from the foregoing causes. No claims for labor or other expenses will be recognized. This warranty is in lieu of and to the exclusion of all other warranties expressed or implied, statutory or otherwise.

**VULCAN INDUSTRIES** shall not be liable for any claims, losses, labor, expenses or damages, direct or consequential, resulting directly or indirectly from the use of, or the inability to use, its products, or for other consequential loss or damage of any nature arising from any cause.

**THIS WARRANTY IS THE SOLE WARRANTY OF VULCAN INDUSTRIES AND ANY OTHER WARRANTIES EXPRESS, IMPLIED IN LAW, IMPLIED IN FACT, INCLUDING WARRANTIES OR MERCHANTABILITY AND FITNESS FOR USE, ARE HEREBY SPECIFICALLY EXCLUDED.**

**PROJECT: Wichita, KS**

**PROJECT NO. 19177**



212 S. KIRLIN ST. MISSOURI VALLEY, IA. 51555  
 (712) 642-2755 or fax (712) 642-4256  
 Email [www.vulcanindustries.com](http://www.vulcanindustries.com)

## SERVICE REPORT

**DATE:** 7/31/20

Representative:	Ray Lindsey Company	Job Name:	Wichita, KS
Contractor:	Wildcat Construction	Job No.:	19177
Engineering Firm:	Professional Engineering Consultants	Equip SN #:	2-VMR-450-3&435-4 /TF
Service Technician:	Ward Hayden		177-450-8/ EWP-450-6

- Reason for call:**
- PRE-GROUT INSPECTION
  - START UP
  - WARRANTY WORK
  - SERVICE

**Material Provided:**

**Comments:**

I arrived on 7/27/20 at 7:00 a.m. I did installation and electrical checks per check lists on all equipment. I checked motor rotation and test ran. I worked with Jay Zimmer, Vulcan Industries, Inc., on programming changes. I ran the screens in low speed by the timer and the high differential level both work as intended. I raised the high high-level float and checked the high high up stream level and both ran the screens in high speed.

I arrived on 7/28/20 at 8:30 a.m. Plant personnel wanted the numbering on electrical panels to be Panel #1 screens # 1 & 3 and panel #2 screens # 2 & 4. I changed them.

I arrived on 7/29/2020 at 8:00 a.m. I trained plant personnel. I changed labels on electrical panels to read Panel #1 Screens 1 & 3 and panel #2 screens # 2 & 4. I changed screen numbers to match.

Note: Contractor needs 1- Large sticker for screen cover that reads "Caution starts automatically" and Touch up Paint red.

Return Trip Required: **NO**

**Material Needed (if any):**

**Vulcan Industries person of contact:**

Mark Hoffman  
General Manager  
712-642-2755

**Job site person(s) of contact:**

**Phone #'s:**

\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

**JOB SITE HOURS:**

Date:	7/27/20	From:	7:00 a.m.	To:	4:00 p.m.	From:		To:	
Date:	7/28/20	From:	8:30 a.m.	To:	3:30 p.m.	From:		To:	
Date:	7/29/20	From:	8:00 a.m.	To:	10:30 a.m.	From:		To:	
Date:		From:		To:		From:		To:	
Date:		From:		To:		From:		To:	

**As a minimum, ONE of the following signatures required when conducting pre-grout inspection, start-up and warranty repairs:**

\_\_\_\_\_  
Contractor Representative

Phone #: \_\_\_\_\_  
Fax #: \_\_\_\_\_

\_\_\_\_\_  
Engineering Representative

Phone #: \_\_\_\_\_  
Fax #: \_\_\_\_\_

**Following signatures are required when conducting requested service repairs:**

\_\_\_\_\_  
Plant Manager / Maintenance Manager

Phone #: \_\_\_\_\_  
Fax #: \_\_\_\_\_



\_\_\_\_\_  
Service Technician

**(Signatures of Contractor/Plant Manager Constitutes Agreement of Above Hours)**