



## HYDRO GATE LIMITED WARRANTY

We warrant each of our Hydro Gate products to be free from defects in material and workmanship for a period of eighteen (18) months from the date of shipment for all goods, provided that such product was both: (1) under normal use and service and used for the purposes and under the conditions for which such product is intended; and (2) installed and maintained according to our instructions and applicable local codes.

Our obligations under this warranty are conditioned upon prompt written notice of the defect from the purchaser. If any our Hydro Gate product is proven to have failed to conform to the above stated warranty, then we, at our sole option, shall refund, repair, or replace the defective Hydro Gate product (F.O.B. the point of manufacture). We shall have the right to inspect the Hydro Gate product for which a claim is made under this warranty. If we request such an inspection, then the purchaser must return the Hydro Gate product to us, transportation prepaid.

This warranty does not cover failure of any Hydro Gate product caused by external forces such as, but not limited to, acts of God or the elements, civil insurrection, vandalism, vehicular or other impact, application of excessive torque to the operating mechanism, presence of foreign matter, or frost heave. The Purchaser shall assume all responsibility and expense for removal, reinstallation, and shipping charges in connection with this warranty.

THIS WARRANTY IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING SPECIFICALLY, THE WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE AND ANY WARRANTIES OF NON-INFRINGEMENT OF THIRD PARTY RIGHTS. IN NO EVENT SHALL WE BE RESPONSIBLE OR LIABLE FOR ANY INCIDENTAL OR CONSEQUENTIAL DAMAGE. FURTHER, WE HEREBY LIMIT OUR TOTAL LIABILITY TO THE VALUE OF THE HYDRO GATE PRODUCT SOLD.

*For more information about Hydro Gate or to view our full line of water products, please visit [www.hydrogate.com](http://www.hydrogate.com) or call Hydro Gate customer service at 1.800.423.1323.*

Mueller refers to one or more of Mueller Water Products, Inc., a Delaware corporation ("MWP"), and its subsidiaries. MWP and each of subsidiaries are legally separate and independent entities when providing products and services. MWP does not provide products or services to third parties. MWP and each of its subsidiaries are liable only for their own acts and omissions and not those of each other. MWP brands include Mueller®, Echologics®, Hydro Gate®, Hydro-Guard®, Jones®, Mi.Net®, Milliken®, Pratt®, Singer®, and U.S. Pipe Valve & Hydrant. Please see [www.muellerwp.com/about](http://www.muellerwp.com/about) to learn more.

Copyright © 2019 Henry Pratt Company, LLC. All Rights Reserved. The trademarks, logos and service marks displayed in this document are the property of Mueller Water Products, Inc., its affiliates or other third parties. Products marked with a section symbol (§) are subject to patents or patent applications. For details, visit [www.mwppat.com](http://www.mwppat.com). These products are intended for use in potable water applications. Please contact your Mueller Sales or Customer Service Representative concerning any other application(s).



MID-AMERICA VALVE  
PO Box 6007  
Leawood, KS 66206  
913-642-2442  
f 913-642-2878

### INSTALLATION AND STARTUP CHECKLIST

Customer Name: Wildcat Construction  
Job Site: Wichita WWTP Plant 1  
Tag #: \_\_\_\_\_  
Serial #: 2590303  
Gate Description: 96 x 108 Slide Gate (North)

- Gate(s) is(are) properly installed
- Actuator rotation is correct
- Gate and Actuator are correctly lubricated
- Actuator voltage and amperage verified
- Gate has been cycled three (3) times per specification for proper operation
- Gate and Actuator are prepared for full-time operation

**Comments:**

7/30/2020 - Gate is properly installed - Operator  
checked out - Limit switches & torque switches set. Gate  
open & closed twice to check operation. City of  
Wichita on site & observed operation

Equipment Manufacturer's Name: Hydro Gate  
Signature of Authorized Representative: Todd Nason  
Date: 7/30/2020 Printed Name: TODD NASON  
Employer: Mid-America Valve  
Address: PO Box 6007, Leawood, KS 66206  
Phone: 913-642-2442



## INSTALLATION AND STARTUP CHECKLIST

Customer Name: Wildcat Construction  
Job Site: Wichita WWTP Plant 1  
Tag #: \_\_\_\_\_  
Serial #: 2580303  
Gate Description: 96 X 108 Slide Gate (south)

- Gate(s) is(are) properly installed
- Actuator rotation is correct
- Gate and Actuator are correctly lubricated
- Actuator voltage and amperage verified
- Gate has been cycled three (3) times per specification for proper operation
- Gate and Actuator are prepared for full-time operation

### Comments:

4/29/2020 - Gate is properly installed. Operator was  
set up, limit switch/torque switches were set. Gate  
open/closed twice to check operation. City of Wichita  
personnel on site + observed operation.

Equipment Manufacturer's Name: Hydro Gate  
Signature of Authorized Representative: Todd Nesom  
Date: 4/29/2020 Printed Name: Todd Nesom  
Employer: Mid-America Valve  
Address: PO Box 6007, Leawood KS 66206  
Phone: 913-642-2442