

## 5234CPS1EME097 Weekly PM CHENEY Generator and Battery Fluid Level Inspections

### Checklist

- 1 Generator #1 Check all hoses and connections for dripping fluids. Tighten hose clamps if needed.
- 3 Generator #1 Check Coolant level, add if needed
- 4 Generator #1 Check Inlet and outlet hose temperature of Block Heater hoses to verify operation
- 6 Generator #1 Check relief bores of water pump for signs of leakage
- 5 Generator #1 Check signal ring position of service indicator on air filter
- 7 Generator #1 Verify batteries are full of acid, cables are tight and battery posts are clean.
- 9 Generator #1 Visually inspect Battery Charger to verify proper operation
- 8 Generator #1 Visually inspect belts for damage or fraying
- 2 Generator #1 Check engine oil level, add in needed and record amount added
- 10 Carry out test run of #1 Generator
- 11 Carry out test run of #2 Generator
- 12 19 Emergency Backup batteries Clean, check connections and electrolyte level
- 13 19 Emergency backup batteries, Check Clean battery charger and surrounding area