

5716SEB1MME025 Semi-Annual PM SEB, UPS maintenance

Checklist

- 1 Check operating environment for clean, cool, dry conditions
- 2 Inspect and clean the cabinet
- 3 Check operation of the fans(power modules)
- 4 Check and tighten all connections
- 5 View and record the alarm and inverter logs.
- 6 Check the UPS System Batteries
- 7 Check the displayed UPS readings against actual readings and recalibrate if needed
- 8 Perform UPS system test
- 9 Check and record the values of the parameters in the system status
- 10 Place UPS System back online and on Battery
- 11 Check the MOV Surge Suppression pack
- 12 Create new WO for any issues that require greater attention