

7501WTP1MME032 Monthly MWTP PM Chlorine Scrubber Damper Test

Checklist

- 1 Note Supply EOV valve open before test
- 2 Place Chlorine Storage Area Scrubber Damper in Manual
- 3 Open Scrubber Damper and Verify Open
- 4 Close Scrubber Damper and Verify Closed
- 5 Place Chlorine Storage Area Scrubber Damper back in Auto
- 6 Place Chlorinator Room Scrubber Damper in Manual
- 7 Open Chlorinator Room Scrubber Damper and Verify open.
- 8 Close Chlorinator Room Scrubber Damper and Verify Closed
- 9 Place Chlorinator Room Scrubber Damper back in Auto
- 10 Place Chlorine Evaporator Room Scrubber Damper in Manual
- 11 Open Chlorine Evaporator Room Scrubber Damper and Verify Open
- 12 Close Chlorine Evaporator Room Scrubber Damper and Verify Closed
- 13 Place Chlorine Evaporator Room Scrubber Damper Back in Auto