

## 7502HPS1MME001 HPS MONTHLY SAFETY EQUIPMENT MAINTENANCE

### Checklist

- 1 verify extinguisher is readily identifiable and unobstructed
- 2 verify extinguisher is properly mounted to the wall
- 3 visually inspect extinguisher for signs of physical damage, corrosion or leakage
- 4 verify tag is intact and legible, initialed by certified person within last 12 months
- 5 Verify pull pin is intact and tamper seal is unbroken
- 6 verify operating instructions are legible and face out when mounted
- 7 check nozzle and hose for damage or obstructions
- 8 verify pressure gauge or indicator is in normal operating range
- 9 wipe down extinguisher and return to proper location initial back of tag when complete
- 10 create a new work order for any additional repairs needed or completed during inspection
- 11 Test operation of emergency lights.