

5214A1T1MME002 Monthly PM GENERATOR ASR PHASE 1SWTP

Checklist

- 1 Record the date of the inspection and readings.
- 2 Record the Generator Testing operation hours.
- 3 Record the Generator Emergency operation hours.
- 4 Check air filter, clean and or replace air filter units.
- 5 Check hoses, belts, exhaust system, muffler, and exhaust pipe.
- 6 Check engine coolant level of coolant in the radiator and add approved coolant, if needed.
- 7 Check engine oil level from the oil dipstick and the amount of oil added to the engine.
- 8 Check the battery charger visually inspect battery charger to verify operation and charge rate.
- 9 Check that the circuit breaker is closed.
- 10 Check for oil leaks and inspect lubrication system hoses and connectors.
- 11 Check for fuel leaks and inspect fuel system hoses and connectors.
- 12 Ensure adequate fuel levels added fuel if needed.
- 13 Ensure that the generator is in ?Auto? mode, for automatic startup.
- 14 Inspect the enclosure and the wiring and accessories.
- 15 Verify that the unit ran and has no alarms or warnings.