

5234CPS1EME036      Semi Annual PM Cheney Backup Battery Charger Operational Check

Checklist

- 1      Check AC input Voltage, DC output voltage and ripple voltage
- 2      Check all electrical connections and wiring.
- 3      Check integrity of remote sense or temperature compensation wiring
- 4      Check voltage and alarm settings
- 5      Exercise front panel controls
- 6      Perform functional tests on battery charger
- 7      test front panel indicators