

7528CPS1MME010      Monthly Cheney Pump Station PM Fire Extinguishers Maintenance

Checklist

- 1      Verify extinguisher is readily identifiable and unobstructed
- 2      Verify extinguisher is properly mounted to the wall.
- 3      Visually inspect extinguisher for signs of physical damage corrosion or leakage
- 4      Verify tag is intact and legible. Verify inspection by certified person within 12 months
- 5      Verify pressure gauge or indicator is in normal operating range
- 6      Verify pool pin is intact and tamper seal is unbroken.
- 7      Verify operating instructions are legible and face out
- 8      Check nozzle and hose for damage or obstructions
- 9      Wipe down extinguisher and return to proper location