

5121CPS1MME013

Checklist

- 1 Check for proper operation of hydraulic valves. Check for leaks
- 2 Visually inspect Gate hoist, check for leaks
- 3 Cycle and check for proper operation of all gate valves
- 4 Inspect gate position indicator. Check fasteners. Check cables and pulleys are clean and move freely
- 5 Inspect emergency gate hangers for condition