

5300EWF1MME001 Quarterly Wellfield PM Wells 1 through 20 Visual  
Inspection checklist for Well Piping Systems

- 1 Check for any piping leaks, any valves leaking and any evidence of past leaks.
- 2 Check pipe hangers, supports, braces that are missing, damaged or corroded.
- 3 Check for any significant vibration or evidence of excessive movement.
- 4 Check for deterioration/damage of weather seals, missing jackets, plugs, or insulation.
- 5 Check for any discoloration indicating leakage or any retaining bands missing/broken.
- 6 Check for coating or paint deterioration, any areas with scale, pits, or rust.
- 7 Check for any corrosion between flanges, any significant corrosion of flange bolts.
- 8 If any issues are found that cannot be corrected at this time, create a new corrective maintenance work order to address issues.