

## Monthly PM Fire Extinguisher Check List

Using the Asset list, perform the following steps on each Fire Extinguisher.

1. Verify extinguisher is readily identifiable and unobstructed.
2. Verify extinguisher is properly mounted to the wall or in its case.
3. Visually inspect extinguisher for signs of physical damage, corrosion or leakage.
4. Verify pressure gauge or indicator is in normal operating range.
5. Verify pull pin is intact and tamper seal is unbroken.
6. Verify operating instructions are legible and face out.
7. Check nozzle and hose for damage or obstructions.
8. Wipe down extinguisher. and return to proper location.
9. Verify tag is intact and legible. Verify inspection by certified person within 12 months. Initial and Date this tag upon successful completion of inspection.
10. Return to proper location.