



WICHITA, KANSAS

**ADDENDUM NO. 2
TO THE Bid 203112**

Hess Pump Station Valve Replacement
(1401 West Museum Boulevard)

448-90958 W9004

TO BE BID: April 24, 2020

The following changes and additions shall be made to the plans and proposal.

1. **SUPPLEMENTAL PROVISIONS – SECTION 33 12 16 VALVES AND APPURTENANCES:**
CLARIFICATION Electric motor actuators are for open-close service.
2. **SUPPLEMENTAL PROVISIONS – SECTION 33 12 16 VALVES AND APPURTENANCES:**
CLARIFICATION Valve motor operators shall be sized for the full AWWA Class 150B rating.
3. **SUPPLEMENTAL PROVISIONS – SECTION 33 12 16 VALVES AND APPURTENANCES:**
CLARIFICATION No specific manufacturer is required for manual operators.
4. **G002 KEY MAP AND GENERAL NOTES:** **CLARIFICATION** The storage location referenced in Construction Sequence Note 3 for the removed valves is still to be determined, but will be within the Hess Pump Station Facility site.
5. **G002 KEY MAP AND GENERAL NOTES / BID FORM:** **CLARIFICATION** The bid item “Valves Shipment” of 1 Each includes one combined shipment of the five valves described in Construction Sequence Note 4.

Each bidder is required to acknowledge receipt of this Addendum by his signature affixed hereto and to file same with and attached to his bid. Any Bid Proposal that is returned without all addenda signed and included in the Proposal shall be considered an invalid Proposal.

April 21, 2020

Gary Janzen, P.E.
City Engineer

Date _____

Signature of Bidder

BIDDER: _____
(print or type name of firm)

ADDRESS: _____

AUTHORIZED AGENT: _____
(Signature)

(print or type name of authorized agent)